

MULTISPLIT DUAL 14



REV15 - 23/06/2026

		OU NEXYA S5 E + IU WALL NEXYA S5																
OUTDOOR UNIT	DUAL SPLIT 14	OS-CANMH14EI																
INDOOR UNIT	WALL 9 / 12	OS-SANQH09EI / OS-SANQH12EI																
Available combinations																		
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class						
	IU combinations	Each room (kW)		Total (kW)			(kW)											
		A	B	min	nominal	max	min	rating	max									
1 unit	9	2,60	—	1,10	2,60	3,20	0,10	0,80	1,00	3,25	—	—						
	12	3,50	—	1,15	3,50	3,80	0,12	1,08	1,35	3,25	—	—						
2 units	9+9	2,05	2,05	1,23	4,10	5,10	0,18	1,23	1,65	3,33	6,80	A++						
	9+12	1,76	2,35	1,23	4,11	5,15	0,18	1,23	1,67	3,34	6,82	A++						
	12+12	2,11	2,11	1,26	4,25	4,64	0,18	1,23	1,46	3,46	7,05	A++						
Available combinations																		
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season				
	IU combinations	Each room (kW)		Total (kW)			(kW)											
		A	B	min	nominal	max	min	rating	max									
1 unit	9	2,93	—	0,83	2,93	3,60	0,13	0,78	0,98	3,74	—	—	—	—				
	12	3,81	—	1,08	3,81	4,05	0,14	1,02	1,27	3,74	—	—	—	—				
2 units	9+9	2,05	2,05	1,23	4,10	4,80	0,15	1,00	1,50	4,10	4,0	A+	5,2	A+++				
	9+12	1,76	2,35	1,23	4,11	4,82	0,15	1,00	1,51	4,13	4,0	A+	5,2	A+++				
	12+12	2,16	2,16	1,30	4,32	4,84	0,15	1,03	1,52	4,18	4,1	A+	5,56	A+++				
		OU NEXYA S5 E + IU WALL NEXYA																
OUTDOOR UNIT	DUAL SPLIT 14	OS-CANMH14EI																
INDOOR UNIT	WALL 9 / 12	OS-SENEH09EI / OS-SENEH12EI/OS-SENEH18EI																
Available combinations																		
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class						
	IU combinations	Each room (kW)		Total (kW)			(kW)											
		A	B	min	nominal	max	min	rating	max									
1 unit	9	2,50	—	1,23	2,50	3,20	0,30	0,77	0,96	3,25	—	—						
	12	3,50	—	1,23	3,50	3,90	0,30	1,08	1,35	3,25	—	—						
	18	4,10	—	1,35	4,10	4,90	0,40	1,27	1,59	3,23	—	—						
2 units	9+9	2,05	2,05	1,76	4,10	4,92	0,44	1,27	1,59	3,23	5,60	A+						
	9+12	1,95	2,14	1,76	4,09	4,91	0,38	1,07	1,34	3,82	6,70	A++						
Available combinations																		
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season				
	IU combinations	Each room (kW)		Total (kW)			(kW)											
		A	B	min	nominal	max	min	rating	max									
1 unit	9	2,92	—	1,32	2,90	3,36	0,28	0,78	0,97	3,73	—	—	—	—				
	12	3,75	—	1,32	3,80	4,31	0,28	1,02	1,28	3,72	—	—	—	—				
	18	4,40	—	1,45	4,40	5,24	0,38	1,19	1,48	3,71	—	—	—	—				
2 units	9+9	2,20	2,20	1,89	4,40	5,28	0,42	1,19	1,48	3,71	3,8	A	—	—				
	9+12	1,90	2,53	1,91	4,44	5,33	0,36	1,02	1,28	4,34	3,9	A	5,88	A+++				
		OU NEXYA S5 E + IU DUCT S6 NEXYA																
OUTDOOR UNIT	DUAL SPLIT 14	OS-CANMH14EI																
INDOOR UNIT	DUCT 9/12/18	OS-SEDAH09EI/OS-SEDAH12EI/OS-SEDAH18EI																
Available combinations																		
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class						
	IU combinations	Each room (kW)		Total (kW)			(kW)											
		A	B	min	nominal	max	min	rating	max									
1 unit	9	2,64	—	0,79	2,64	2,90	0,11	0,74	0,89	3,54	—	—						
	12	3,20	—	0,96	3,20	3,52	0,15	0,99	1,19	3,23	—	—						
2 units	9+9	2,04	2,04	1,22	4,08	4,48	0,19	1,26	1,52	3,23	6,10	A++						
	9+12	1,75	2,34	1,23	4,09	4,50	0,19	1,26	1,52	3,25	6,10	A++						
Available combinations																		
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season				
	IU combinations	Each room (kW)		Total (kW)			(kW)											
		A	B	min	nominal	max	min	rating	max									
1 unit	9	2,63	—	0,79	2,63	2,89	0,09	0,59	0,71	4,45	—	—	—	—				
	12	3,51	—	1,05	3,51	3,87	0,14	0,90	1,08	3,90	—	—	—	—				
2 units	9+9	2,20	2,20	1,32	4,39	4,83	0,14	0,94	1,12	4,67	4,2	A+	5,5	A+++				
	9+12	1,89	2,51	1,32	4,40	4,84	0,15	1,01	1,21	4,36	4	A+	5,3	A+++				
		OU NEXYA S5 E + IU DUCT NEXYA																
OUTDOOR UNIT	DUAL SPLIT 14	OS-CANMH14EI																
INDOOR UNIT	DUCT 9/12/18	OS-SANDH09EI / OS-SANDH12EI / OS-SANDH18EI																
Available combinations																		
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class						
	IU combinations	Each room (kW)		Total (kW)			(kW)											
		A	B	min	nominal	max	min	rating	max									
1 unit	9	2,50	—	1,23	2,50	3,20	0,30	0,77	0,96	3,25	—	—						
	12	3,50	—	1,23	3,50	3,90	0,30	1,08	1,35	3,25	—	—						
	18	4,10	—	1,35	4,10	4,90	0,40	1,27	1,59	3,23	—	—						
2 units	9+9	2,05	2,05	1,76	4,10	4,92	0,44	1,27	1,59	3,23	6,10	A++						
	9+12	2,09	2,12	1,81	4,22	5,06	0,38	1,09	1,37	3,87	6,66	A++						
Available combinations																		
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season				
	IU combinations	Each room (kW)		Total (kW)			(kW)											
		A	B	min	nominal	max	min	rating	max									
1 unit	9	2,92	—	1,32	2,90	3,36	0,28	0,78	0,97	3,73	—	—	—	—				
	12	3,75	—	1,32	3,80	4,31	0,28	1,02	1,28	3,72	—	—	—	—				
	18	4,40	—	1,45	4,40	5,24	0,38	1,19	1,48	3,71	—	—	—	—				
2 units	9+9	2,20	2,20	1,89	4,40	5,28	0,42	1,19	1,48	3,71	3,8	A	—	—				
	9+12	1,92	2,55	1,92	4,47	5,37	0,35	1,01	1,26	4,44	4,3	A+	5,18	A+++				
		OU NEXYA S5 E + IU CASSETTE S6 NEXYA																
OUTDOOR UNIT	DUAL SPLIT 14	OS-CANMH14EI																
INDOOR UNIT	CASSETTE 9/12/18	OS-SENAH09EI/OS-SENAH12EI/OS-SENAH18EI																
Available combinations																		
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class						
	IU combinations	Each room (kW)		Total (kW)			(kW)											
		A	B	min	nominal	max	min	rating	max									
1 unit	9	2,64	—	0,79	2,64	2,90	0,11	0,71	0,85	3,71	—	—						
	12	3,54	—	1,06	3,54	3,90	0,16	1,08	1,30	3,27	—	—						

2 units	9 + 9	2,03	2,03	1,22	4,07	4,47	0,18	1,22	1,47	3,33	6,29	A++		
	9+12	1,76	2,35	1,23	4,11	4,52	0,18	1,21	1,46	3,40	6,50	A++		
Available combinations														
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season
	IU combinations	Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
1 unit	9	2,42	—	0,73	2,42	2,67	0,10	0,65	0,78	3,71	—	—	—	—
	12	3,30	—	0,99	3,30	3,64	0,13	0,89	1,07	3,71	—	—	—	—
2 units	9+9	2,20	2,20	1,32	4,40	4,84	0,18	1,18	1,42	3,73	3,80	A	4,99	A++
	9+12	1,90	2,54	1,33	4,44	4,88	0,18	1,19	1,39	3,73	3,90	A	5,20	A+++
		OU NEXYA S5 E + IU CASSETTE NEXYA												
OUTDOOR UNIT	DUAL SPLIT 14	OS-CANMH14EI												
INDOOR UNIT	CASSETTE 9/12/18	OS-SANCH09EI / OS-SANCH12EI / OS-SANCH18EI												
Available combinations														
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class		
	IU combinations	Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
1 unit	9	2,50	—	1,23	2,50	3,20	0,30	0,77	0,96	3,25	—	—		
	12	3,50	—	1,23	3,50	3,90	0,30	1,08	1,35	3,25	—	—		
	18	4,10	—	1,35	4,10	4,90	0,40	1,27	1,59	3,23	—	—		
2 units	9 + 9	2,05	2,05	1,76	4,10	4,92	0,44	1,27	1,59	3,23	6,1	A++		
	9+12	1,90	2,34	1,82	4,23	5,08	0,40	1,14	1,43	3,71	6,56	A++		
Available combinations														
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season
	IU combinations	Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
1 unit	9	2,92	—	1,32	2,90	3,36	0,28	0,78	0,97	3,73	—	—	—	—
	12	3,75	—	1,32	3,80	4,31	0,28	1,02	1,28	3,72	—	—	—	—
	18	4,40	—	1,45	4,40	5,24	0,38	1,19	1,48	3,71	—	—	—	—
2 units	9+9	2,20	2,20	1,89	4,40	5,28	0,42	1,19	1,48	3,71	3,8	A	—	—
	9+12	1,89	2,51	1,89	4,40	5,28	0,37	1,04	1,31	4,21	4,24	A+	5,50	A+++

MULTISPLIT DUAL 18

		OU NEXYA S5 E + IU WALL NEXYA S5													
OUTDOOR UNIT		DUAL SPLIT 18		OS-CANMH18EI											
INDOOR UNIT		WALL 9 / 12 /18		OS-SANQH09EI / OS-SANQH12EI/ OS-SANQH18EI											
Available combinations															
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class			
	IU combinations	Each room (kW)		Total (kW)			(kW)								
		A	B	min	nominal	max	min	rating	max						
1 unit	12	3,50	—	0,38	3,50	3,80	0,13	1,08	1,35	3,25	-	-			
	18	5,20	—	0,40	5,20	5,90	0,16	1,61	2,01	3,23	-	-			
2 units	9 + 9	2,65	2,65	0,46	5,30	6,00	0,21	1,42	1,99	3,73	6,70	A++			
	9+12	2,28	3,03	0,46	5,31	6,01	0,21	1,42	1,99	3,74	6,71	A++			
	9+18	1,78	3,56	0,46	5,33	6,04	0,21	1,41	1,97	3,78	6,79	A++			
	12+12	2,66	2,66	0,46	5,32	6,02	0,21	1,42	1,99	3,74	6,73	A++			
	12+18	2,14	3,21	0,46	5,34	6,05	0,21	1,41	1,98	3,79	6,81	A++			
Available combinations															
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season	
	IU combinations	Each room (kW)		Total (kW)			(kW)								
		A	B	min	nominal	max	min	rating	max						
1 unit	12	3,81	—	1,08	3,81	4,05	0,14	1,02	1,27	3,74	-	-	-	-	
	18	5,40	—	1,30	5,40	6,10	0,16	1,44	1,80	3,74	-	-	-	-	
2 units	9+9	2,75	2,75	1,65	5,50	6,23	0,21	1,42	1,67	3,87	4,00	A+	5,20	A+++	
	9+12	2,36	3,15	1,65	5,51	6,24	0,21	1,41	1,70	3,90	4,01	A+	5,18	A+++	
	9+18	1,83	3,67	1,65	5,50	6,23	0,19	1,28	1,53	4,31	4,05	A+	5,49	A+++	
	12+12	2,76	2,76	1,65	5,51	6,24	0,21	1,41	1,69	3,91	4,03	A+	5,17	A+++	
	12+18	2,20	3,30	1,65	5,50	6,23	0,19	1,27	1,53	4,32	4,05	A+	5,49	A+++	
		OU NEXYA S5 E + IU WALL NEXYA													
OUTDOOR UNIT		DUAL SPLIT 18		OS-CANMH18EI											
INDOOR UNIT		WALL 9 / 12		OS-SENEH09EI / OS-SENEH12EI/OS-SENEH18EI											
Available combinations															
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class			
	IU combinations	Each room (kW)		Total (kW)			(kW)								
		A	B	min	nominal	max	min	rating	max						
1 unit	9	2,50	—	1,43	2,50	3,20	0,35	0,75	0,93	3,35	—	—			
	12	3,50	—	1,43	3,50	3,90	0,35	1,08	1,29	3,25	—	—			
	18	5,00	—	1,64	5,00	5,51	0,45	1,55	1,89	3,23	—	—			
2 units	9 + 9	2,65	2,65	2,12	5,30	6,41	0,54	1,64	2,05	3,23	6,10	A++			
	9+12	2,27	3,03	2,12	5,17	6,41	0,54	1,38	2,05	3,76	6,75	A++			
	12+12	2,65	2,65	2,12	5,28	6,41	0,54	1,38	2,05	3,82	6,94	A++			
Available combinations															
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season	
	IU combinations	Each room (kW)		Total (kW)			(kW)								
		A	B	min	nominal	max	min	rating	max						
1 unit	9	3,00	—	1,56	3,00	3,63	0,32	0,80	1,00	3,75	—	—	—	—	
	12	3,80	—	1,56	3,80	4,60	0,32	1,00	1,20	3,81	—	—	—	—	
	18	5,20	—	1,73	5,20	5,79	0,42	1,35	1,88	3,85	—	—	—	—	
2 units	9+9	2,78	2,78	2,23	5,57	6,68	0,51	1,50	1,88	3,71	3,80	A	5,10	A+++	
	9+12	2,39	3,18	2,23	5,54	6,68	0,51	1,39	1,88	3,99	4,23	A+	5,15	A+++	
	12+12	2,79	2,79	2,23	5,62	6,68	0,51	1,37	1,88	4,10	4,34	A+	5,28	A+++	
		OU NEXYA S5 E + IU DUCT S6 NEXYA													
OUTDOOR UNIT		DUAL SPLIT 18		OS-CANMH18EI											
INDOOR UNIT		DUCT 9/12/18		OS-SEDAH09EI/OS-SEDAH12EI/OS-SEDAH18EI											
Available combinations															
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class			
	IU combinations	Each room (kW)		Total (kW)			(kW)								
		A	B	min	nominal	max	min	rating	max						
	12	3,52	—	1,06	3,52	3,87	0,14	0,96	1,16	3,65	—	—			
	18	5,32	—	1,59	5,32	5,85	0,25	1,65	1,98	3,23	—	—			
2 units	9+9	2,78	2,78	1,67	5,57	6,13	0,24	1,60	1,92	3,48	6,50	A++			
	9+12	2,39	3,19	1,67	5,58	6,13	0,24	1,60	1,92	3,49	6,50	A++			
	12+12	2,79	2,79	1,67	5,58	6,14	0,24	1,60	1,92	3,49	6,50	A++			
	Available combinations														
Heating		Heating capacity					Power input								

		Each room (kW)		Total (kW)			(kW)			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season
		A	B	min	nominal	max	min	rating	max					
	12	3,53	—	1,06	3,53	3,89	0,13	0,85	1,02	4,17	—	—	—	—
	18	5,44	—	1,63	5,44	5,99	0,22	1,47	1,76	3,71	—	—	—	—
2 units	9+9	2,93	2,93	1,76	5,86	6,45	0,22	1,45	1,74	4,04	3,90	A	5,10	A+++
	9+12	2,51	3,35	1,76	5,86	6,45	0,22	1,45	1,74	4,04	4,00	A+	5,10	A+++
	12+12	2,93	2,93	1,76	5,87	6,45	0,22	1,45	1,74	4,05	4,00	A+	5,10	A+++
		OU NEXYA S5 E + IU DUCT NEXYA												
OUTDOOR UNIT	DUAL SPLIT 18	OS-CANMH18EI												
INDOOR UNIT	DUCT 9/12/18	OS-SANDH09EI / OS-SANDH12EI / OS-SANDH18EI												
Available combinations														
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class		
	IU combinations	Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
1 unit	9	2,50	—	1,43	2,50	3,20	0,35	0,75	0,93	3,35	—	—		
	12	3,50	—	1,43	3,50	3,90	0,35	1,08	1,29	3,25	—	—		
	18	5,00	—	1,64	5,00	5,51	0,45	1,55	1,89	3,23	—	—		
2 units	9+9	2,65	2,65	2,12	5,30	6,41	0,54	1,64	2,05	3,23	6,10	A++		
	9+12	2,27	3,03	2,12	5,50	6,41	0,54	1,55	2,05	3,56	6,67	A++		
	12+12	2,65	2,65	2,12	5,51	6,41	0,54	1,55	2,05	3,56	6,65	A++		
Available combinations														
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season
	IU combinations	Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
1 unit	9	3,00	—	1,56	3,00	3,63	0,32	0,80	1,00	3,75	—	—	—	—
	12	3,80	—	1,56	3,80	4,60	0,32	1,00	1,20	3,81	—	—	—	—
	18	5,20	—	1,73	5,20	5,79	0,42	1,35	1,88	3,85	—	—	—	—
2 units	9+9	2,78	2,78	2,23	5,57	6,68	0,51	1,50	1,88	3,71	3,80	A	5,10	A+++
	9+12	2,39	3,18	2,23	5,57	6,68	0,51	1,35	1,88	4,12	4,39	A+	5,02	A++
	12+12	2,79	2,79	2,23	5,54	6,68	0,51	1,38	1,88	4,02	4,35	A+	4,95	A++
		OU NEXYA S5 E + IU CASSETTE S6 NEXYA												
OUTDOOR UNIT	DUAL SPLIT 18	OS-CANMH18EI												
INDOOR UNIT	CASSETTE 9/12/18	OS-SENAH09EI/OS-SENAH12EI/OS-SENAH18EI												
Available combinations														
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class		
	IU combinations	Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
	12	3,53	—	1,06	3,53	3,88	0,15	0,88	1,18	3,58	—	—		
	18	5,21	—	1,56	5,21	5,73	0,24	1,60	1,92	3,25	—	—		
2 units	9+9	2,64	2,64	1,58	5,28	5,80	0,24	1,63	1,96	3,24	6,30	A++		
	9+12	2,26	3,02	1,58	5,28	5,81	0,24	1,57	1,88	3,36	6,22	A++		
	12+12	2,63	2,63	1,58	5,25	5,78	0,23	1,51	1,81	3,48	6,67	A++		
Available combinations														
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season
	IU combinations	Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
	12	3,51	—	1,05	3,51	3,87	0,13	0,86	1,03	4,08	—	—	—	—
	18	5,56	—	1,67	5,56	6,12	0,21	1,39	1,67	3,99	—	—	—	—
2 units	9+9	2,78	2,78	1,67	5,57	6,13	0,23	1,50	1,80	3,71	4,0	A+	5,10	A+++
	9+12	2,40	3,19	1,68	5,59	6,15	0,21	1,40	1,68	4,00	4,1	A+	5,25	A+++
	12+12	2,79	2,79	1,68	5,58	6,14	0,20	1,32	1,58	4,23	4,1	A+	5,38	A+++
		OU NEXYA S5 E + IU CASSETTE NEXYA												
OUTDOOR UNIT	DUAL SPLIT 18	OS-CANMH18EI												
INDOOR UNIT	CASSETTE 9/12/18	OS-SANCH09EI / OS-SANCH12EI / OS-SANCH18EI												
Available combinations														
Cooling		Cooling capacity					Power input			EER (W/W)	SEER	Energy Class		
	IU combinations	Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
1 unit	9	2,50	—	1,43	2,50	3,20	0,35	0,75	0,93	3,35	—	—		
	12	3,50	—	1,43	3,50	3,90	0,35	1,08	1,29	3,25	—	—		
	18	5,00	—	1,64	5,00	5,51	0,45	1,55	1,89	3,23	—	—		
2 units	9+9	2,65	2,65	2,12	5,30	6,41	0,54	1,64	2,05	3,23	6,1	A++		
	9+12	2,27	3,03	2,12	5,44	6,41	0,54	1,55	2,05	3,52	6,6	A++		
	12+12	2,65	2,65	2,12	5,48	6,41	0,54	1,51	2,05	3,62	6,8	A++		
Available combinations														
Heating		Heating capacity					Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer Season
	IU combinations	Each room (kW)		Total (kW)			(kW)							
		A	B	min	nominal	max	min	rating	max					
1 unit	9	3,00	—	1,56	3,00	3,63	0,32	0,80	1,00	3,75	—	—	—	—
	12	3,80	—	1,56	3,80	4,60	0,32	1,00	1,20	3,81	—	—	—	—
	18	5,20	—	1,73	5,20	5,79	0,42	1,35	1,88	3,85	—	—	—	—
2 units	9+9	2,78	2,78	2,23	5,57	6,68	0,51	1,50	1,88	3,71	4,0	A+	5,10	A+++
	9+12	2,39	3,18	2,23	5,48	6,68	0,51	1,44	1,88	3,81	4,2	A+	5,28	A+++
	12+12	2,79	2,79	2,23	5,55	6,68	0,51	1,39	1,88	4,00	4,3	A+	5,30	A+++

MULTISPLIT TRIAL 21

		OU NEXYA S5 E + IU WALL NEXYA S5												
OUTDOOR UNIT	TRIAL SPLIT 21	OS-CANMH21EI												
INDOOR UNIT	WALL 9 / 12 / 18	OS-SANQH09EI / OS-SANQH12EI/ OS-SANQH18EI												
Available combinations														
Cooling		Cooling capacity						Power input			EER (W/W)	SEER	Energy Class	
	UI combinations	Each room (kW)			Total (kW)			(kW)						
		A	B	C	min	nominal	max	min	rating	max				
2 units	9+9	2,61	2,61	—	1,57	5,22	5,74	0,21	1,39	1,67	3,75	7,45	A++	
	9+12	2,66	3,55	—	1,86	6,21	6,83	0,28	1,88	2,25	3,31	7,46	A++	
	9+18	2,06	4,11	—	1,85	6,17	6,79	0,27	1,81	2,17	3,41	7,41	A++	
	12+12	3,08	3,08	—	1,85	6,16	6,78	0,28	1,85	2,22	3,34	7,48	A++	
	12+18	2,47	3,71	—	1,85	6,18	6,80	0,27	1,81	2,17	3,41	7,43	A++	
3 units	9+9+9	2,07	2,07	2,07	1,89	6,20	6,80	0,25	1,72	2,05	3,60	7,10	A++	
	9+9+12	1,86	1,86	2,48	1,89	6,21	6,83	0,26	1,73	2,07	3,60	7,11	A++	
	9+12+12	1,67	2,22	2,22	1,89	6,22	6,84	0,26	1,75	2,10	3,55	7,08	A++	
	12+12+12	2,04	2,04	2,04	1,89	6,23	6,84	0,25	1,68	2,11	3,71	7,22	A++	
Available combinations														
Heating		Heating capacity						Power input						

		Each room (kW)			Total (kW)			(kW)			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
		A	B	C	min	nominal	max	min	rating	max					
2 units	9+9	2,64	2,64	—	1,58	5,28	5,81	0,20	1,36	1,63	3,89	4,09	A+	5,34	A+++
	9+12	2,58	3,44	—	1,81	6,02	6,62	0,24	1,62	1,95	3,71	4,07	A+	5,32	A+++
	9+18	2,07	4,14	—	1,86	6,21	6,83	0,22	1,50	1,79	4,15	4,21	A+	5,71	A+++
	12+12	3,04	3,04	—	1,82	6,07	6,68	0,25	1,64	1,96	3,71	4,08	A+	5,30	A+++
	12+18	2,49	3,73	—	1,86	6,21	6,83	0,22	1,49	1,79	4,17	4,22	A+	5,71	A+++
3 units	9+9+9	2,07	2,07	2,07	1,83	6,20	6,90	0,22	1,46	1,68	4,25	4,20	A+	5,60	A++ +
	9+9+12	1,86	1,86	2,48	1,86	6,20	6,82	0,22	1,46	1,75	4,26	4,21	A+	5,6	A+++
	9+12+12	1,70	2,26	2,26	1,87	6,22	6,84	0,24	1,57	1,89	3,96	4,13	A+	5,09	A++
	12+12+12	2,08	2,08	2,08	1,87	6,25	6,87	0,23	1,56	1,87	4,01	4,16	A+	5,239025933	A+++
		OU NEXYA SS E + IU WALL NEXYA													
OUTDOOR UNIT	TRIAL SPLIT 21	OS-CANMH21EI													
INDOOR UNIT	WALL 9 / 12 / 18	OS-SENEH09EI / OS-SENEH12EI / OS-SENEH18EI													
Available combinations															
Cooling		Cooling capacity						Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,50	—	—	1,43	3,50	3,90	0,38	1,08	1,30	3,23	—	—		
	18	5,00	—	—	1,65	5,00	6,50	0,48	1,55	1,78	3,23	—	—		
2 units	9+9	2,65	2,65	—	2,01	5,30	6,41	0,57	1,64	2,08	3,23	5,60	A+		
	9+12	2,57	3,43	—	2,01	6,00	6,59	0,57	1,86	2,12	3,23	5,60	A+		
	9+18	2,03	4,07	—	2,01	6,25	6,83	0,57	1,74	2,17	3,59	6,90	A++		
	12+12	3,05	3,05	—	2,01	6,10	6,83	0,57	1,89	2,17	3,23	5,60	A+		
3 units	9+9+9	2,03	2,03	2,03	2,44	6,10	7,32	0,68	1,89	2,36	3,23	6,10	A++		
	9+9+12	1,86	1,86	2,48	2,48	6,20	7,44	0,62	1,73	2,16	3,58	6,82	A++		
Available combinations															
Heating		Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,80	—	—	1,43	3,80	4,60	0,35	1,02	1,23	3,71	—	—	—	—
	18	5,20	—	—	1,74	5,20	6,64	0,45	1,40	2,00	3,71	—	—	—	—
2 units	9+9	2,95	2,95	—	2,13	5,90	6,77	0,52	1,59	1,91	3,71	3,80	A	—	—
	9+12	2,70	3,60	—	2,13	6,30	6,96	0,52	1,70	1,95	3,71	3,80	A	—	—
	9+18	2,20	4,40	—	2,13	6,19	7,22	0,52	1,49	2,00	4,15	3,96	A	—	—
	12+12	3,15	3,15	—	2,13	6,30	7,22	0,52	1,70	2,00	3,71	3,80	A	—	—
3 units	9+9+9	2,15	2,15	2,15	2,26	6,45	7,74	0,63	1,74	2,17	3,71	4,00	A+	4,80	A++ +
	9+9+12	1,89	1,89	2,52	2,20	6,29	7,55	0,51	1,43	1,78	4,41	3,95	A	5,42	A+++
		OU NEXYA SS E + IU DUCT S6 NEXYA													
OUTDOOR UNIT	TRIAL SPLIT 21	OS-CANMH21EI													
INDOOR UNIT	DUCT 9 / 12 / 18	OS-SEDAH09EI/OS-SEDAH12EI/OS-SEDAH18EI													
Available combinations															
Cooling		Cooling capacity						Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,47	—	—	1,04	3,47	3,82	0,14	0,92	1,10	3,79	—	—		
	18	5,24	—	—	1,57	5,24	5,77	0,22	1,48	1,77	3,55	—	—		
2 units	9+9	2,59	2,59	—	1,55	5,18	5,70	0,20	1,34	1,61	3,87	6,56	A++		
	9+12	2,67	3,56	—	1,87	6,23	6,85	0,27	1,78	2,14	3,50	6,52	A++		
	9+18	2,08	4,15	—	1,87	6,23	6,85	0,26	1,71	2,05	3,65	6,64	A++		
	12+12	3,09	3,09	—	1,85	6,17	6,79	0,26	1,75	2,10	3,53	6,53	A++		
3 units	9+9+9	2,08	2,08	2,08	1,87	6,23	6,85	0,25	1,65	1,98	3,78	6,42	A++		
	9+9+12	1,85	1,85	2,47	1,87	6,18	6,86	0,26	1,71	2,05	3,61	6,40	A++		
Available combinations															
Heating		Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,51	—	—	1,05	3,51	3,86	0,13	0,84	1,00	4,20	—	—	—	—
	18	5,24	—	—	1,57	5,24	5,77	0,21	1,38	1,66	3,79	—	—	—	—
2 units	9+9	2,74	2,74	—	1,65	5,49	6,03	0,18	1,18	1,42	4,64	4,12	A+	5,13	A+++
	9+12	2,76	3,68	—	1,93	6,44	7,08	0,22	1,50	1,80	4,29	4,10	A+	5,08	A++
	9+18	2,15	4,31	—	1,94	6,46	7,10	0,22	1,48	1,78	4,37	4,00	A+	5,13	A+++
	12+12	3,22	3,22	—	1,93	6,44	7,08	0,22	1,50	1,80	4,30	4,10	A+	5,08	A++
3 units	9+9+9	2,14	2,14	2,14	1,92	6,42	7,06	0,20	1,32	1,59	4,86	4,22	A+	5,33	A+++
	9+9+12	1,94	1,94	2,58	1,94	6,46	7,11	0,22	1,48	1,77	4,36	4,20	A+	5,20	A+++
		OU NEXYA SS E + IU DUCT NEXYA													
OUTDOOR UNIT	TRIAL SPLIT 21	OS-CANMH21EI													
INDOOR UNIT	DUCT 9 / 12 / 18	OS-SANDH09EI / OS-SANDH12EI / OS-SANDH18EI													
Available combinations															
Cooling		Cooling capacity						Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,50	—	—	1,43	3,50	3,90	0,38	1,08	1,30	3,23	—	—		
	18	5,00	—	—	1,65	5,00	6,50	0,48	1,55	1,78	3,23	—	—		
2 units	9+9	2,65	2,65	—	2,01	5,30	6,41	0,57	1,64	2,08	3,23	5,60	A+		
	9+12	2,57	3,43	—	2,01	6,00	6,59	0,57	1,86	2,12	3,23	5,60	A+		
	9+18	2,10	4,20	—	2,01	6,30	6,83	0,57	1,94	2,17	3,24	5,60	A+		
	12+12	3,10	3,10	—	2,01	6,20	6,83	0,57	1,92	2,17	3,23	5,60	A+		
3 units	9+9+9	2,03	2,03	2,03	2,44	6,10	7,32	0,68	1,89	2,36	3,23	6,10	A++		
	9+9+12	2,07	2,07	2,21	2,54	6,35	7,62	0,66	1,84	2,30	3,45	6,38	A++		
Available combinations															
Heating		Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,80	—	—	1,43	3,80	4,60	0,35	1,02	1,23	3,71	—	—	—	—
	18	5,20	—	—	1,74	5,20	6,64	0,45	1,40	2,00	3,71	—	—	—	—
2 units	9+9	2,95	2,95	—	2,13	5,90	6,77	0,52	1,59	1,91	3,71	3,80	A	—	—
	9+12	2,70	3,60	—	2,13	6,30	6,96	0,52	1,70	1,95	3,71	3,80	A	—	—
	9+18	2,20	4,40	—	2,13	6,60	7,22	0,52	1,78	2,00	3,71	3,80	A	—	—
	12+12	3,15	3,15	—	2,13	6,30	7,22	0,52	1,70	2,00	3,71	3,80	A	—	—
3 units	9+9+9	2,15	2,15	2,15	2,26	6,45	7,74	0,63	1,74	2,17	3,71	3,80	A	4,00	A++
	9+9+12	1,93	1,93	2,57	2,25	6,42	7,70	0,49	1,35	1,69	4,75	4,05	A+	5,38	A+++
		OU NEXYA SS E + IU CASSETTE S6 NEXYA													

OUTDOOR UNIT		TRIAL SPLIT 21		OS-CANMH21EI											
INDOOR UNIT		CASSETTE 9/12/18		OS-SENAH09EI/OS-SENAH12EI/OS-SENAH18EI											
Available combinations															
Cooling		Cooling capacity						Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,52	—	—	1,05	3,52	3,87	0,14	0,96	1,15	3,67	—	—		
	18	5,32	—	—	1,60	5,32	5,85	0,24	1,58	1,89	3,37	—	—		
2 units	9+9	2,61	2,61	—	1,56	5,21	5,74	0,23	1,52	1,83	3,43	6,34	A++		
	9+12	2,63	3,51	—	1,84	6,14	6,76	0,30	1,81	2,36	3,39	6,35	A++		
	9+18	2,05	4,10	—	1,84	6,15	6,76	0,27	1,83	2,19	3,36	6,02	A+		
	12+12	3,09	3,09	—	1,85	6,17	6,79	0,29	1,91	2,29	3,23	6,48	A++		
3 units	9+9+9	2,05	2,05	2,05	1,85	6,16	6,77	0,28	1,86	2,23	3,32	6,30	A++		
	9+9+12	1,92	1,92	2,36	1,85	6,20	6,77	0,28	1,85	2,23	3,35	6,40	A++		
Available combinations															
Heating		Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,25	—	—	0,98	3,25	3,58	0,13	0,88	1,05	3,71	—	—	—	—
	18	5,03	—	—	1,51	5,03	5,53	0,20	1,36	1,63	3,71	—	—	—	—
2 units	9+9	2,65	2,65	—	1,65	5,30	6,07	0,26	1,42	2,09	3,73	3,8	A	4,56	A+
	9+12	2,68	3,62	—	1,93	6,30	7,09	0,31	1,69	2,46	3,73	3,9	A	4,74	A++
	9+18	2,12	4,25	—	1,94	6,37	7,12	0,27	1,71	2,15	3,72	4,1	A+	4,91	A++
	12+12	3,20	3,20	—	1,94	6,40	7,11	0,29	1,72	2,31	3,72	4,0	A	4,88	A++
3 units	9+9+9	2,14	2,14	2,14	1,93	6,45	7,08	0,26	1,74	2,08	3,71	4,04	A+	5,04	A++
	9+9+12	1,89	1,89	2,52	1,93	6,46	7,11	0,28	1,74	2,20	3,71	4,10	A+	5,10	A+++
		OU NEXYA S5 E + IU CASSETTE NEXYA													
OUTDOOR UNIT		TRIAL SPLIT 21		OS-CANMH21EI											
INDOOR UNIT		CASSETTE 9/12/18		OS-SANCH09EI/ OS-SANCH12EI / OS-SANCH18EI											
Available combinations															
Cooling		Cooling capacity						Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,50	—	—	1,43	3,50	3,90	0,38	1,08	1,30	3,23	—	—		
	18	5,00	—	—	1,65	5,00	6,50	0,48	1,55	1,78	3,23	—	—		
2 units	9+9	2,65	2,65	—	2,01	5,30	6,41	0,57	1,64	2,08	3,23	5,60	A+		
	9+12	2,57	3,43	—	2,01	6,00	6,59	0,57	1,86	2,12	3,23	5,60	A+		
	9+18	2,03	4,07	—	2,01	6,10	6,83	0,57	1,88	2,17	3,24	5,60	A+		
	12+12	3,05	3,05	—	2,01	6,10	6,83	0,57	1,89	2,17	3,23	5,60	A+		
3 units	9+9+9	2,03	2,03	2,03	2,44	6,10	7,32	0,68	1,89	2,36	3,23	6,10	A++		
	9+9+12	1,92	1,92	2,36	2,48	6,19	7,43	0,66	1,82	2,28	3,40	6,41	A++		
Available combinations															
Heating		Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	12	3,80	—	—	1,43	3,80	4,60	0,35	1,02	1,23	3,71	—	—	—	—
	18	5,20	—	—	1,74	5,20	6,64	0,45	1,40	2,00	3,71	—	—	—	—
2 units	9+9	2,95	2,95	—	2,13	5,90	6,77	0,52	1,59	1,91	3,71	3,8	A	—	—
	9+12	2,70	3,60	—	2,13	6,30	6,96	0,52	1,70	1,95	3,71	3,8	A	—	—
	9+18	2,20	4,40	—	2,13	6,60	7,22	0,52	1,78	2,00	3,71	3,8	A	—	—
	12+12	3,15	3,15	—	2,13	6,30	7,22	0,52	1,70	2,00	3,71	3,8	A	—	—
3 units	9+9+9	2,15	2,15	2,15	2,26	6,45	7,74	0,63	1,74	2,17	3,71	4,0	A+	5,10	A+++
	9+9+12	1,89	1,89	2,52	2,21	6,31	7,57	0,52	1,44	1,80	4,39	4,1	A+	5,75	A+++
MULTISPLIT NEXYA WHR S5 E QUADRI INVERTER 27															
		OU NEXYA WHR S5 E + IU NEXYA S5													
OUTDOOR UNIT		TRIAL SPLIT 21		OS-CEMAH27EI											
INDOOR UNIT		WALL 9/12/18/24		OS-SANQH09EI/OS-SANQH12EI/OS-SANQH18EI/OS-SANQH24EI											
Available combinations															
Cooling		Cooling capacity						Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
1 units	18	5,21	—	—	1,56	5,21	5,73	0,23	1,52	1,83	3,42	—	—		
	24	6,81	—	—	2,04	6,81	7,49	0,32	2,11	2,54	3,22	—	—		
2 units	9+9	2,58	2,58	—	1,55	5,15	5,67	0,20	1,34	1,61	3,85	7,68	A++		
	9+12	2,61	3,47	—	1,82	6,08	6,69	0,25	1,67	2,00	3,65	7,64	A++		
	9+18	2,62	5,25	—	2,36	7,87	8,66	0,36	2,40	2,88	3,28	7,56	A++		
	12+12	3,49	3,49	—	2,09	6,97	7,67	0,31	2,04	2,45	3,41	7,51	A++		
3 units	12+18	3,15	4,72	—	2,36	7,87	8,66	0,36	2,40	2,88	3,28	7,56	A++		
	9+9+9	2,63	2,63	2,63	2,37	7,90	8,50	0,33	2,22	2,85	3,55	7,70	A++		
	9+9+12	2,37	2,37	3,16	2,37	7,91	8,70	0,33	2,23	2,67	3,55	7,72	A++		
	9+9+18	1,98	1,98	3,97	2,38	7,93	8,72	0,33	2,19	2,63	3,62	7,89	A++		
	9+12+12	2,16	2,88	2,88	2,38	7,92	8,71	0,33	2,22	2,67	3,56	7,73	A++		
	9+12+18	1,83	2,44	3,66	2,38	7,94	8,73	0,33	2,19	2,63	3,62	7,90	A++		
12+12+12	2,61	2,61	2,61	2,35	7,83	8,61	0,33	2,19	2,62	3,58	7,77	A++			
Available combinations															
Heating		Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)			Total (kW)			(kW)							
		A	B	C	min	nominal	max	min	rating	max					
	18	5,25	—	—	1,57	5,25	5,77	0,21	1,41	1,69	3,72	—	—	—	—
	24	7,12	—	—	2,14	7,12	7,83	0,33	2,22	2,67	3,20	—	—	—	—
2 units	9+9	2,71	2,71	—	1,62	5,41	5,95	0,22	1,46	1,75	3,71	3,99	A	5,07	A++
	9+12	2,60	3,47	—	1,82	6,07	6,67	0,25	1,64	1,96	3,71	4,02	A+	4,99	A++
	9+18	2,56	5,11	—	2,30	7,67	8,44	0,31	2,03	2,44	3,77	4,26	A+	5,50	A+++
	12+12	3,29	3,29	—	1,97	6,57	7,23	0,27	1,77	2,13	3,71	4,03	A+	4,85	A++
3 units	12+18	3,07	4,60	—	2,30	7,67	8,44	0,31	2,03	2,44	3,77	4,26	A+	5,50	A+++
	9+9+9	2,73	2,73	2,73	2,46	8,20	10,20	0,32	2,15	2,95	3,81	4,30	A+	5,50	A+++
	9+9+12	2,46	2,46	3,28	2,46	8,21	10,21	0,32	2,15	2,58	3,82	4,31	A+	5,51	A+++
	9+9+18	2,07	2,07	4,14	2,48	8,27	10,29	0,29	1,93	2,32	4,28	4,36	A+	5,77	A+++
	9+12+12	2,24	2,99	2,99	2,47	8,22	10,22	0,32	2,14	2,57	3,84	4,32	A+	5,51	A+++
	9+12+18	1,91	2,55	3,82	2,48	8,28	10,30	0,29	1,93	2,32	4,29	4,36	A+	5,78	A+++
12+12+12	2,74	2,74	2,74	2,47	8,23	10,24	0,32	2,14	2,57	3,85	4,32	A+	5,52	A+++	
		OU NEXYA WHR S5 E + IU NEXYA													
OUTDOOR UNIT		TRIAL SPLIT 21		OS-CEMAH27EI											
INDOOR UNIT		WALL 9/12/18/24		OS-SENEH09EI/OS-SENEH12EI/OS-SENEH18EI/OS-SENEH24EI											
Available combinations															

Cooling capacity		Power input									EER (W/W)	SEER	Energy Class		
UI combinations	Each room (kW)			Total (kW)			(kW)								
	A	B	C	min	nominal	max	min	rating	max						
1 units	18	5,32	—	—	1,60	5,32	5,86	0,24	1,62	1,95	3,28	—	—		
	24	6,91	—	—	2,07	6,91	7,60	0,35	2,34	2,81	2,96	—	—		
2 units	9+9	2,64	2,64	—	1,58	5,27	5,80	0,23	1,50	1,80	3,51	6,17	A++		
	9+12	2,61	3,48	—	1,83	6,10	6,71	0,27	1,81	2,17	3,37	5,93	A+		
	9+18	2,40	4,80	—	2,16	7,20	7,92	0,33	2,23	2,67	3,23	6,04	A+		
	12+12	3,40	3,40	—	2,04	6,80	7,48	0,32	2,11	2,53	3,23	5,66	A+		
	12+18	3,00	4,50	—	2,25	7,50	8,25	0,35	2,32	2,79	3,23	5,94	A+		
3 units	9+9+9	2,64	2,64	2,64	2,37	7,91	8,70	0,37	2,45	2,94	3,23	6,30	A++		
	9+9+12	2,38	2,38	3,17	2,38	7,92	8,71	0,37	2,45	2,94	3,23	6,07	A+		
	9+9+18	1,96	1,96	3,92	2,35	7,83	8,62	0,34	2,29	2,75	3,42	6,30	A++		
	9+12+12	2,14	2,86	2,86	2,36	7,86	8,65	0,35	2,36	2,83	3,34	5,86	A+		
	9+12+18	1,81	2,41	3,62	2,35	7,84	8,62	0,35	2,32	2,78	3,38	5,84	A+		
12+12+12	2,64	2,64	2,64	2,38	7,93	8,72	0,35	2,36	2,83	3,36	5,93	A+			
Available combinations															
Heating		Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
UI combinations	Each room (kW)			Total (kW)			(kW)								
	A	B	C	min	nominal	max	min	rating	max						
1 units	18	5,21	—	—	1,56	5,21	5,73	0,24	1,61	1,93	3,24	—	—	—	—
	24	7,04	—	—	2,11	7,04	7,74	0,36	2,37	2,84	2,97	—	—	—	—
2 units	9+9	2,30	2,30	—	1,38	4,60	5,06	0,19	1,24	1,49	3,71	3,77	A	4,74	A++
	9+12	2,27	3,03	—	1,59	5,30	5,83	0,21	1,43	1,71	3,71	3,86	A	4,71	A++
	9+18	2,27	4,53	—	2,04	6,80	7,48	0,27	1,83	2,20	3,71	3,88	A	4,76	A++
	12+12	3,05	3,05	—	1,83	6,10	6,71	0,25	1,64	1,97	3,71	3,88	A	4,74	A++
	12+18	2,76	4,14	—	2,07	6,90	7,59	0,28	1,86	2,23	3,71	3,89	A	4,76	A++
3 units	9+9+9	2,74	2,74	2,74	2,46	8,21	9,03	0,33	2,21	2,65	3,71	4,10	A+	5,10	A+++
	9+9+12	2,43	2,43	3,25	2,43	8,12	8,93	0,32	2,15	2,58	3,78	4,10	A+	5,10	A+++
	9+9+18	2,04	2,04	4,08	2,45	8,15	8,97	0,30	2,02	2,43	4,03	4,04	A+	5,10	A+++
	9+12+12	2,22	2,96	2,96	2,44	8,14	8,96	0,32	2,13	2,55	3,82	4,10	A+	5,10	A+++
	9+12+18	1,88	2,51	3,76	2,45	8,15	8,97	0,33	2,18	2,62	3,73	3,66	A	5,10	A+++
12+12+12	2,72	2,72	2,72	2,45	8,17	8,98	0,32	2,11	2,53	3,87	4,10	A+	5,10	A+++	
		OU NEXYA WHR S5 E + IU DUCT S6													
OUTDOOR UNIT	TRIAL SPLIT 21	OS-CEMAH27EI													
INDOOR UNIT	DUCT 9/12/18/24	OS-SEDAH09EI/OS-SEDAH12EI/OS-SEDAH18EI/OS-SEDAH24EI													
Available combinations															
Cooling		Cooling capacity						Power input			EER (W/W)	SEER	Energy Class		
UI combinations	Each room (kW)			Total (kW)			(kW)								
	A	B	C	min	nominal	max	min	rating	max						
1 units	18	5,28	—	—	1,58	5,28	5,81	0,25	1,69	2,03	3,12	—	—		
	24	7,07	—	—	2,12	7,07	7,78	0,36	2,38	2,86	2,97	—	—		
2 units	9+9	2,57	2,57	—	1,54	5,13	5,65	0,22	1,48	1,78	3,47	6,24	A++		
	9+12	2,61	3,49	—	1,83	6,10	6,71	0,28	1,85	2,23	3,29	6,21	A++		
	9+18	2,50	5,01	—	2,25	7,51	8,26	0,35	2,33	2,79	3,23	6,16	A++		
	12+12	3,32	3,32	—	1,99	6,65	7,31	0,31	2,06	2,47	3,23	6,16	A++		
	12+18	3,01	4,52	—	2,26	7,53	8,28	0,35	2,33	2,80	3,23	6,17	A++		
3 units	9+9+9	2,64	2,64	2,64	2,46	7,91	8,21	0,18	2,45	2,90	3,23	6,30	A++		
	9+9+12	2,38	2,38	3,17	2,38	7,92	8,71	0,37	2,45	2,94	3,23	6,30	A++		
	9+9+18	1,97	1,97	3,93	2,36	7,87	8,65	0,36	2,38	2,85	3,31	6,40	A++		
	9+12+12	2,13	2,84	2,84	2,35	7,82	8,60	0,36	2,41	2,89	3,25	6,33	A++		
	9+12+18	1,82	2,42	3,63	2,36	7,87	8,66	0,36	2,38	2,85	3,31	6,40	A++		
12+12+12	2,64	2,64	2,64	2,38	7,93	8,73	0,37	2,45	2,94	3,23	6,30	A++			
Available combinations															
Heating		Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
UI combinations	Each room (kW)			Total (kW)			(kW)								
	A	B	C	min	nominal	max	min	rating	max						
	18	5,20	—	—	1,56	5,20	5,72	0,23	1,56	1,87	3,33	—	—	—	—
	24	6,97	—	—	2,09	6,97	7,67	0,32	2,16	2,59	3,23	—	—	—	—
2 units	9+9	2,67	2,67	—	1,60	5,34	5,88	0,21	1,37	1,64	3,90	3,81	A	4,74	A++
	9+12	2,71	3,61	—	1,89	6,31	6,95	0,26	1,70	2,04	3,71	3,84	A	4,71	A++
	9+18	2,55	5,10	—	2,29	7,65	8,41	0,31	2,06	2,47	3,71	3,86	A	4,76	A++
	12+12	3,43	3,43	—	2,06	6,87	7,55	0,28	1,85	2,22	3,71	3,86	A	4,74	A++
	12+18	3,07	4,61	—	2,31	7,68	8,45	0,31	2,07	2,49	3,71	3,86	A	4,76	A++
3 units	9+9+9	2,74	2,74	2,74	2,29	8,21	8,79	0,35	2,05	3,00	4,00	4,10	A+	5,10	A+++
	9+9+12	2,46	2,46	3,28	2,46	8,21	9,03	0,31	2,05	2,46	4,01	4,10	A+	5,10	A+++
	9+9+18	2,04	2,04	4,08	2,45	8,16	8,97	0,30	1,98	2,38	4,12	4,01	A+	5,09	A++
	9+12+12	2,24	2,99	2,99	2,46	8,21	9,04	0,31	2,05	2,46	4,01	4,10	A+	5,10	A+++
	9+12+18	1,88	2,51	3,77	2,45	8,17	8,98	0,30	1,97	2,37	4,14	4,01	A+	5,09	A++
12+12+12	2,70	2,70	2,70	2,43	8,09	8,90	0,30	2,00	2,40	4,05	4,10	A+	5,10	A+++	
		OU NEXYA WHR S5 E + IU CASSETTE S6													
OUTDOOR UNIT	TRIAL SPLIT 21	OS-CEMAH27EI													
INDOOR UNIT	CASSETTE 9/12/18/24	OS-SENAH09EI/OS-SENAH12EI/OS-SENAH18EI//OS-SANCH24EI													
Available combinations															
Cooling		Cooling capacity						Power input			EER (W/W)	SEER	Energy Class		
UI combinations	Each room (kW)			Total (kW)			(kW)								
	A	B	C	min	nominal	max	min	rating	max						
1 units	18	5,42	—	—	1,63	5,42	5,97	0,23	1,56	1,88	3,47	—	—		
	24	7,20	—	—	2,16	7,20	7,92	0,34	2,27	2,72	3,18	—	—		
2 units	9+9	2,63	2,63	—	1,58	5,27	5,80	0,22	1,49	1,78	3,55	6,36	A++		
	9+12	2,62	3,50	—	1,84	6,12	6,73	0,27	1,77	2,12	3,46	6,45	A++		
	9+18	2,63	5,26	—	2,37	7,88	8,67	0,37	2,44	2,93	3,23	6,46	A++		
	12+12	3,51	3,51	—	2,11	7,02	7,72	0,32	2,11	2,53	3,33	6,41	A++		
	12+18	3,16	4,75	—	2,37	7,91	8,70	0,36	2,38	2,85	3,33	6,66	A++		
3 units	9+9+9	2,64	2,64	2,64	2,87	7,91	8,32	0,14	2,45	2,85	3,23	6,30	A++		
	9+9+12	2,39	2,39	3,19	2,39	7,97	8,76	0,36	2,40	2,88	3,32	6,44	A++		
	9+9+18	1,98	1,98	3,96	2,38	7,92	8,71	0,34	2,29	2,74	3,46	6,52	A++		
	9+12+12	2,15	2,87	2,87	2,37	7,88	8,67	0,35	2,30	2,76	3,42	6,59	A++		
	9+12+18	1,82	2,43	3,65	2,37	7,90	8,69	0,33	2,23	2,68	3,54	6,63	A++		
12+12+12	2,66	2,66	2,66	2,39	7,98	8,78	0,35	2,30	2,76	3,47	6,64	A++			
Available combinations															
Heating		Heating capacity						Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
UI combinations	Each room (kW)			Total (kW)			(kW)								

		A	B	C	min	nominal	max	min	rating	max					
1 units	18	5,39	—	—	1,62	5,39	5,93	0,21	1,42	1,70	3,79	—	—	—	—
	24	7,16	—	—	2,15	7,16	7,88	0,28	1,86	2,24	3,84	—	—	—	—
2 units	9+9	2,65	2,65	—	1,59	5,29	5,82	0,21	1,43	1,71	3,71	4,14	A+	4,53	A+
	9+12	2,74	3,65	—	1,92	6,38	7,02	0,26	1,72	2,07	3,71	4,35	A+	4,63	A++
	9+18	2,73	5,45	—	2,45	8,18	9,00	0,33	2,19	2,63	3,74	4,61	A++	5,02	A++
	12+12	3,70	3,70	—	2,22	7,41	8,15	0,30	1,99	2,39	3,71	4,54	A+	4,97	A++
	12+18	3,28	4,92	—	2,46	8,20	9,02	0,31	2,08	2,49	3,95	4,73	A++	5,18	A+++
3 units	9+9+9	2,74	2,74	2,74	1,76	8,21	9,53	0,26	2,21	2,85	3,71	4,60	A++	5,10	A+++
	9+9+12	2,47	2,47	3,30	2,47	8,24	9,07	0,31	2,09	2,50	3,95	4,75	A++	5,31	A+++
	9+9+18	2,05	2,05	4,10	2,46	8,20	9,02	0,28	1,89	2,27	4,35	4,79	A++	5,39	A+++
	9+12+12	2,25	2,99	2,99	2,47	8,24	9,06	0,30	1,99	2,39	4,14	4,79	A++	5,42	A+++
	9+12+18	1,91	2,55	3,82	2,48	8,28	9,11	0,28	1,86	2,23	4,46	4,82	A++	5,48	A+++
	12+12+12	2,74	2,74	2,74	2,46	8,21	9,03	0,29	1,90	2,29	4,31	4,88	A++	5,52	A+++

MULTISPLIT QUADRI 28

		OU NEXYA S4 E + IU WALL NEXYA S5														
OUTDOOR UNIT	QUADRI SPLIT 28	OS-CEMYH28EI														
INDOOR UNIT	WALL 9 / 12/18/24	OS-SANQH09EI / OS-SANQH12EI/ OS-SANQH18EI/ OS-SANQH24EI														
Available combinations																
Cooling		Cooling capacity							Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					
2 units	9+9	2,56	2,56	—	—	1,54	5,12	5,63	0,19	1,27	1,53	4,02	7,86	A++		
	9+12	2,61	3,48	—	—	1,82	6,08	6,69	0,24	1,60	1,92	3,81	7,71	A++		
	9+18	2,60	5,20	—	—	2,34	7,80	8,58	0,34	2,28	2,74	3,42	7,46	A++		
	12+12	3,49	3,49	—	—	2,09	6,98	7,68	0,30	1,98	2,38	3,52	7,46	A++		
	12+18	3,25	4,87	—	—	2,43	8,12	8,93	0,37	2,49	2,98	3,26	7,44	A++		
	12+24	2,53	5,07	—	—	2,43	7,60	8,94	0,36	2,35	2,89	3,23	6,84	A++		
	18+18	4,08	4,08	—	—	2,45	8,15	8,97	0,36	2,41	2,89	3,38	7,58	A++		
	18+24	3,50	4,67	—	—	2,45	8,16	8,98	0,38	2,53	3,03	3,23	7,09	A++		
3 units	9+9+9	2,58	2,58	2,58	—	2,32	7,75	8,52	0,31	2,09	2,51	3,71	7,69	A++		
	9+9+12	2,43	2,43	3,24	—	2,43	8,11	8,92	0,34	2,29	2,74	3,55	7,62	A++		
	9+9+18	2,04	2,04	4,07	—	2,44	8,15	8,96	0,34	2,25	2,70	3,62	7,70	A++		
	9+12+12	2,21	2,95	2,95	—	2,44	8,12	8,93	0,34	2,29	2,74	3,55	7,64	A++		
	9+12+18	1,88	2,51	3,76	—	2,45	8,16	8,97	0,34	2,25	2,70	3,62	7,71	A++		
	9+18+18	1,63	3,26	3,26	—	2,45	8,15	8,97	0,34	2,25	2,70	3,62	7,76	A++		
	12+12+12	2,71	2,71	2,71	—	2,44	8,13	8,94	0,34	2,29	2,75	3,55	7,66	A++		
	12+12+18	2,33	2,33	3,50	—	2,45	8,17	8,98	0,34	2,25	2,70	3,62	7,73	A++		
4 units	12+18+18	2,05	3,08	3,08	—	2,46	8,20	9,02	0,35	2,34	2,81	3,50	7,57	A++		
	9+9+9+9	2,05	2,05	2,05	2,05	2,46	8,20	10,40	0,33	2,21	3,45	3,71	7,70	A++		
	9+9+9+12	1,87	1,87	1,87	2,49	2,43	8,10	10,27	0,33	2,17	2,60	3,74	7,71	A++		
	9+9+9+18	1,62	1,62	1,62	3,25	2,44	8,12	10,30	0,33	2,17	2,60	3,74	7,67	A++		
	9+9+12+12	1,74	1,74	2,32	2,32	2,43	8,11	10,28	0,33	2,17	2,60	3,74	7,72	A++		
	9+9+12+18	1,52	1,52	2,03	3,05	2,44	8,13	10,31	0,33	2,17	2,60	3,75	7,69	A++		
Available combinations																
Heating		Heating capacity							Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					
2 units	9+9	2,65	2,65	—	—	1,59	5,31	5,84	0,21	1,39	1,67	3,82	3,88	A	5,25	A+++
	9+12	2,55	3,40	—	—	1,79	5,95	6,55	0,24	1,60	1,92	3,71	3,86	A	5,13	A+++
	9+18	2,66	5,33	—	—	2,40	7,99	8,79	0,32	2,15	2,59	3,71	4,10	A+	5,62	A+++
	12+12	3,20	3,20	—	—	1,92	6,39	7,03	0,26	1,72	2,07	3,71	3,81	A	4,98	A++
	12+18	3,25	4,88	—	—	2,44	8,13	8,94	0,33	2,19	2,63	3,71	4,11	A+	5,63	A+++
	12+24	2,61	5,23	—	—	2,44	7,84	8,94	0,32	2,11	2,63	3,71	3,65	A	5,15	A+++
	18+18	4,07	4,07	—	—	2,44	8,14	8,95	0,29	1,93	2,32	4,21	4,24	A+	5,58	A+++
	18+24	3,46	4,61	—	—	2,45	8,07	8,97	0,31	2,05	2,46	3,93	3,81	A	5,36	A+++
3 units	9+9+9	2,65	2,65	2,65	—	2,38	7,94	8,73	0,30	2,03	2,43	3,91	4,19	A+	5,59	A+++
	9+9+12	2,45	2,45	3,27	—	2,45	8,17	8,99	0,32	2,11	2,53	3,88	4,20	A+	5,65	A+++
	9+9+18	2,04	2,04	4,09	—	2,45	8,17	8,99	0,28	1,85	2,21	4,43	4,31	A+	5,86	A+++
	9+12+12	2,23	2,98	2,98	—	2,46	8,18	9,00	0,32	2,10	2,52	3,89	4,20	A+	5,66	A+++
	9+12+18	1,89	2,52	3,77	—	2,45	8,18	9,00	0,28	1,84	2,21	4,44	4,32	A+	5,88	A+++
	9+18+18	1,65	3,29	3,29	—	2,47	8,23	9,05	0,26	1,75	2,11	4,69	4,34	A+	6,03	A+++
	12+12+12	2,73	2,73	2,73	—	2,46	8,19	9,01	0,31	2,10	2,51	3,91	4,21	A+	5,66	A+++
	12+12+18	2,34	2,34	3,51	—	2,45	8,18	9,00	0,28	1,84	2,21	4,45	4,33	A+	5,88	A+++
4 units	12+18+18	2,06	3,10	3,10	—	2,48	8,26	9,09	0,26	1,76	2,11	4,69	4,12	A+	5,99	A+++
	9+9+9+9	2,05	2,05	2,05	2,05	2,46	8,20	10,80	0,28	1,91	3,06	4,28	4,20	A+	5,70	A+++
	9+9+9+12	1,89	1,89	1,89	2,53	2,46	8,21	10,81	0,29	1,91	2,30	4,29	4,21	A+	5,71	A+++
	9+9+9+18	1,63	1,63	1,63	3,26	2,45	8,15	10,74	0,27	1,78	2,14	4,57	4,24	A+	5,80	A+++
	9+9+12+12	1,76	1,76	2,35	2,35	2,46	8,21	10,82	0,29	1,91	2,29	4,30	4,22	A+	5,72	A+++
	9+9+12+18	1,53	1,53	2,04	3,06	2,45	8,16	10,75	0,27	1,78	2,14	4,58	4,24	A+	5,80	A+++
			OU NEXYA S4 E + IU WALL NEXYA													
OUTDOOR UNIT	QUADRI SPLIT 28	OS-CEMYH28EI														
INDOOR UNIT	WALL 9 / 12	OS-SENEH09EI / OS-SENEH12EI / OS-SENEH18EI														
Available combinations																
Cooling		Cooling capacity							Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					
1 units	18	5,00	—	—	—	1,72	5,00	6,50	0,50	1,55	1,78	3,23	—	—		
2 units	9+9	2,65	2,65	—	—	2,05	5,30	6,81	0,63	1,64	2,28	3,23	5,10	A		
	9+12	2,57	3,43	—	—	2,05	6,00	6,97	0,63	1,86	2,41	3,23	5,10	A		
	9+18	2,43	4,87	—	—	2,05	7,30	7,54	0,63	2,26	2,79	3,23	5,10	A		
	12+12	3,25	3,25	—	—	2,05	6,50	7,38	0,63	2,01	2,49	3,23	5,10	A		
	12+18	2,92	4,38	—	—	2,05	7,30	7,54	0,63	2,26	2,79	3,23	5,10	A		
3 units	9+9+9	2,37	2,37	2,37	—	2,62	7,10	8,45	0,76	2,20	2,94	3,23	5,60	A+		
	9+9+12	2,34	2,34	3,12	—	2,62	7,80	8,45	0,76	2,41	2,94	3,23	5,60	A+		
	9+9+18	1,95	1,95	3,90	—	2,62	7,80	8,45	0,76	2,41	2,94	3,23	5,60	A+		
	9+12+12	2,13	2,84	2,84	—	2,62	7,80	8,45	0,76	2,41	2,94	3,23	5,60	A+		
	12+12+12	2,60	2,60	2,60	—	2,62	7,80	8,45	0,76	2,41	2,94	3,23	5,60	A+		
4 units	9+9+9+9	2,05	2,05	2,05	2,05	2,87	8,21	9,93	0,86	2,53	3,18	3,24	6,10	A++		
	9+9+9+12	1,89	1,89	1,89	2,53	2,87	8,21	9,93	0,86	2,53	3,18	3,25	6,10	A++		
Available combinations																
Heating		Heating capacity							Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					

		A	B	C	D	min	nominal	max	min	rating	max					
1 units	18	5,60	—	—	—	1,85	5,60	6,77	0,50	1,48	1,70	3,78	—	—	—	—
2 units	9+9	3,00	3,00	—	—	2,20	6,00	7,30	0,55	1,57	2,13	3,81	3,40	A	—	—
	9+12	3,00	4,00	—	—	2,20	7,00	7,47	0,59	1,84	2,25	3,81	3,40	A	—	—
	9+18	2,63	5,27	—	—	2,20	7,90	8,09	0,59	2,05	2,61	3,85	3,40	A	—	—
	12+12	3,75	3,75	—	—	2,20	7,50	7,91	0,59	1,97	2,32	3,81	3,40	A	—	—
	12+18	3,20	4,80	—	—	2,20	8,00	8,09	0,59	2,08	2,61	3,85	3,40	A	—	—
3 units	9+9+9	2,87	2,87	2,87	—	2,81	8,60	9,06	0,66	2,19	2,55	3,92	3,50	A	—	—
	9+9+12	2,58	2,58	3,44	—	2,81	8,60	9,06	0,66	2,19	2,55	3,92	3,50	A	—	—
	9+9+18	2,15	2,15	4,30	—	2,81	8,60	9,06	0,66	2,19	2,55	3,95	3,50	A	—	—
	9+12+12	2,35	3,13	3,13	—	2,81	8,60	9,06	0,66	2,19	2,55	3,92	3,50	A	—	—
	12+12+12	2,87	2,87	2,87	—	2,81	8,60	9,06	0,66	2,19	2,55	3,92	3,50	A	—	—
4 units	9+9+9+9	2,23	2,23	2,23	2,23	3,08	8,90	10,65	0,75	2,22	2,75	4,01	3,80	A	4,6	A++
	9+9+9+12	2,10	2,10	2,10	2,80	3,08	9,10	10,65	0,75	2,27	2,75	4,01	3,80	A	4,6	A++
		OU NEXYA S4 E + IU DUCT S6 NEXYA														
OUTDOOR UNIT	QUADRI SPLIT 28	OS-CEMYH28EI														
INDOOR UNIT	DUCT 9/12/18	OS-SEDAH09EI/OS-SEDAH12EI/OS-SEDAH18EI														
Available combinations																
Cooling		Cooling capacity							Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					
1 units	18	—	—	—	—	—	—	—	—	—	—	—	—	—		
2 units	9+9	2,55	2,55	—	—	1,53	5,10	5,61	0,21	1,37	1,64	3,73	6,20	A++		
	9+12	2,60	3,47	—	—	1,82	6,07	6,67	0,26	1,72	2,07	3,52	6,13	A++		
	9+18	2,62	5,25	—	—	2,36	7,87	8,66	0,36	2,43	2,91	3,24	5,96	A+		
	12+12	3,49	3,49	—	—	2,09	6,97	7,67	0,32	2,14	2,57	3,26	5,97	A+		
	12+18	3,19	4,79	—	—	2,46	7,98	9,01	0,40	2,47	3,19	3,23	5,89	A+		
3 units	9+9+9	2,60	2,60	2,6	—	2,34	7,80	8,58	0,34	2,26	2,71	3,45	6,09	A+		
	9+9+12	2,45	2,45	3,26	—	2,45	8,16	8,98	0,37	2,47	2,97	3,30	6,01	A+		
	9+9+18	2,06	2,06	4,12	—	2,47	8,24	9,06	0,37	2,45	2,94	3,36	6,09	A+		
	9+12+12	2,23	2,97	2,97	—	2,45	8,17	8,98	0,37	2,47	2,97	3,30	6,01	A+		
	12+12+12	2,72	2,72	2,72	—	2,45	8,17	8,99	0,37	2,48	2,97	3,30	6,01	A+		
4 units	9+9+9+9	2,04	2,04	2,04	2,04	2,45	8,15	8,97	0,35	2,35	2,82	3,47	6,04	A+		
	9+9+9+12	1,88	1,88	1,88	2,51	2,45	8,16	8,97	0,35	2,35	2,82	3,47	6,04	A+		
Available combinations																
Heating		Heating capacity							Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					
1 units	18	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2 units	9+9	2,85	2,85	—	—	1,71	5,71	6,28	0,22	1,50	1,80	3,81	3,78	A	4,38	A+
	9+12	2,87	3,83	—	—	2,01	6,70	7,37	0,28	1,77	2,28	3,78	3,76	A	4,27	A+
	9+18	2,89	5,69	—	—	2,60	8,58	9,52	0,40	2,30	3,19	3,73	3,77	A	4,33	A+
	12+12	3,82	3,82	—	—	2,29	7,65	8,41	0,35	2,05	2,80	3,74	3,73	A	4,20	A+
	12+18	3,50	5,25	—	—	2,63	8,75	9,63	0,40	2,35	3,24	3,72	3,77	A	4,34	A+
3 units	9+9+9	2,85	2,85	2,85	—	2,57	8,55	9,41	0,33	2,19	2,63	3,90	4,06	A+	4,71	A++
	9+9+12	2,63	2,63	3,51	—	2,63	8,77	9,65	0,34	2,27	2,73	3,86	4,07	A+	4,70	A++
	9+9+18	2,19	2,19	4,38	—	2,63	8,77	9,64	0,33	2,19	2,63	4,00	4,01	A+	4,79	A++
	9+12+12	2,39	3,19	3,19	—	2,63	8,78	9,65	0,34	2,27	2,73	3,86	4,07	A+	4,70	A++
	12+12+12	2,93	2,93	2,93	—	2,63	8,78	9,66	0,34	2,27	2,72	3,87	4,07	A+	4,71	A++
4 units	9+9+9+9	2,20	2,20	2,20	2,2	2,64	8,81	9,69	0,31	2,06	2,47	4,28	4,13	A+	4,90	A++
	9+9+9+12	2,01	2,01	2,01	2,68	2,61	8,70	9,57	0,30	2,02	2,42	4,31	4,13	A+	4,90	A++
		OU NEXYA S4 E + IU DUCT NEXYA														
OUTDOOR UNIT	QUADRI SPLIT 28	OS-CEMYH28EI														
INDOOR UNIT	DUCT 9/12/18	OS-SANDH09EI / OS-SANDH12EI / OS-SANDH18EI														
Available combinations																
Cooling		Cooling capacity							Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					
1 units	18	5,00	—	—	—	1,72	5,00	6,50	0,50	1,55	1,78	3,23	—	—		
2 units	9+9	2,65	2,65	—	—	2,05	5,30	6,81	0,58	1,64	2,10	3,23	5,10	A		
	9+12	2,57	3,43	—	—	2,05	6,00	6,97	0,58	1,86	2,22	3,23	5,10	A		
	9+18	2,43	4,87	—	—	2,05	7,30	7,54	0,58	2,26	2,57	3,23	5,10	A		
	12+12	3,25	3,25	—	—	2,05	6,50	7,38	0,58	2,01	2,29	3,23	5,10	A		
	12+18	2,92	4,38	—	—	2,05	7,30	7,54	0,58	2,26	2,57	3,23	5,10	A		
3 units	9+9+9	2,37	2,37	2,37	—	2,62	7,10	8,45	0,70	2,20	2,71	3,23	6,10	A++		
	9+9+12	2,34	2,34	3,12	—	2,62	7,80	8,45	0,70	2,41	2,71	3,23	6,10	A++		
	9+9+18	1,95	1,95	3,90	—	2,62	7,80	8,45	0,70	2,41	2,71	3,23	6,10	A++		
	9+12+12	2,13	2,84	2,84	—	2,62	7,80	8,45	0,70	2,41	2,71	3,23	6,10	A++		
	12+12+12	2,60	2,60	2,60	—	2,62	7,80	8,45	0,70	2,41	2,71	3,23	6,10	A++		
4 units	9+9+9+9	2,05	2,05	2,05	2,05	2,87	8,20	9,92	0,79	2,54	2,92	3,23	6,10	A++		
	9+9+9+12	2,01	2,01	2,01	2,03	2,82	8,05	9,74	0,75	2,21	2,76	3,64	6,30	A++		
Available combinations																
Heating		Heating capacity							Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					
1 units	18	5,60	—	—	—	1,85	5,60	6,77	0,50	1,48	1,70	3,78	—	—	—	—
2 units	9+9	3,00	3,00	—	—	2,20	6,00	7,30	0,59	1,57	2,13	3,81	3,40	A	—	—
	9+12	3,00	4,00	—	—	2,20	7,00	7,47	0,59	1,84	2,25	3,81	3,40	A	—	—
	9+18	2,63	5,27	—	—	2,20	7,90	8,09	0,59	2,05	2,61	3,85	3,40	A	—	—
	12+12	3,75	3,75	—	—	2,20	7,50	7,91	0,59	1,97	2,32	3,81	3,40	A	—	—
	12+18	3,20	4,80	—	—	2,20	8,00	8,09	0,59	2,08	2,61	3,85	3,40	A	—	—
3 units	9+9+9	2,87	2,87	2,87	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,50	A	—	—
	9+9+12	2,58	2,58	3,44	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,50	A	—	—
	9+9+18	2,15	2,15	4,30	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,50	A	—	—
	9+12+12	2,35	3,13	3,13	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,50	A	—	—
	12+12+12	2,87	2,87	2,87	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,50	A	—	—
4 units	9+9+9+9	2,20	2,20	2,20	2,20	3,08	8,79	10,64	0,81	2,37	2,96	3,71	3,80	A	—	—
	9+9+9+12	1,92	1,92	1,92	2,53	2,90	8,30	10,04	0,65	1,91	2,39	4,34	4,06	A+	4,83	A++
		OU NEXYA S4 E + IU CASSETTE S6 NEXYA														
OUTDOOR UNIT	QUADRI SPLIT 28	OS-CEMYH28EI														
INDOOR UNIT	CASSETTE 9/12/18	OS-SENAH09EI/OS-SENAH12EI/OS-SENAH18EI														
Available combinations																
Cooling		Cooling capacity							Power input							

	UI combinations	Each room (kW)				Total (kW)			(kW)			EER (W/W)	SEER	Energy Class
		A	B	C	D	min	nominal	max	min	rating	max			
1 units	18	—	—	—	—	—	—	—	—	—	—	—	—	—
2 units	9+9	2,60	2,60	—	—	1,56	5,20	5,72	0,22	1,48	1,77	3,52	6,76	A++
	9+12	2,61	3,48	—	—	1,83	6,09	6,70	0,26	1,76	2,11	3,46	6,85	A++
	9+18	2,64	5,28	—	—	2,38	7,92	8,71	0,36	2,43	2,92	3,26	6,86	A++
	12+12	3,52	3,52	—	—	2,11	7,04	7,74	0,32	2,11	2,53	3,34	6,85	A++
	12+18	3,29	4,93	—	—	2,46	8,22	9,04	0,38	2,53	3,06	3,25	6,93	A++
3 units	9+9+9	2,60	2,60	2,60	—	2,34	7,79	8,56	0,35	2,37	2,84	3,29	6,7	A++
	9+9+12	2,46	2,46	3,28	—	2,46	8,19	9,01	0,38	2,52	3,02	3,25	6,74	A++
	9+9+18	2,05	2,05	4,10	—	2,46	8,20	9,02	0,37	2,48	2,97	3,31	6,76	A++
	9+12+12	2,24	2,98	2,98	—	2,46	8,20	9,02	0,37	2,47	2,96	3,32	6,91	A++
	12+12+12	2,76	2,76	2,76	—	2,48	8,27	9,10	0,37	2,49	2,98	3,33	7,00	A++
4 units	9+9+9+9	2,07	2,07	2,07	2,07	2,48	8,26	9,09	0,38	2,51	3,01	3,30	6,8	A++
	9+9+9+12	1,90	1,90	1,90	2,53	2,47	8,23	9,05	0,37	2,45	2,94	3,36	6,86	A++

Available combinations																
Heating		Heating capacity							Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					
1 units	18	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2 units	9+9	2,62	2,62	—	—	1,70	5,24	6,25	0,30	1,41	2,39	3,71	3,3	B	4,28	A+
	9+12	2,64	3,52	—	—	2,02	6,16	7,39	0,34	1,66	2,73	3,71	3,6	A	4,22	A+
	9+18	2,65	5,37	—	—	2,60	8,02	9,53	0,44	2,16	3,50	3,71	3,8	A	4,70	A++
	12+12	3,62	3,62	—	—	2,30	7,24	8,45	0,38	1,95	3,03	3,71	3,7	A	4,20	A+
	12+18	3,36	4,98	—	—	2,63	8,34	9,66	0,41	2,24	3,28	3,72	3,9	A	4,81	A++
3 units	9+9+9	2,61	2,61	2,61	—	2,57	7,83	9,41	0,44	2,11	3,51	3,71	3,7	A	4,89	A++
	9+9+12	2,50	2,50	3,34	—	2,62	8,34	9,62	0,40	2,24	3,24	3,72	3,9	A	4,95	A++
	9+9+18	2,14	2,14	4,22	—	2,62	8,50	9,59	0,36	2,27	2,87	3,74	4,0	A+	5,01	A++
	9+12+12	2,28	3,02	3,02	—	2,64	8,32	9,68	0,38	2,23	3,07	3,73	4,0	A	5,03	A++
	12+12+12	2,82	2,82	2,82	—	2,62	8,46	9,59	0,36	2,26	2,89	3,74	4,0	A+	4,73	A++
4 units	9+9+9+9	2,19	2,19	2,19	2,19	2,62	8,75	9,62	0,37	2,36	2,97	3,71	4,0	A+	5,14	A+++
	9+9+9+12	2,02	2,02	2,02	2,69	2,63	8,76	9,63	0,36	2,37	2,85	3,71	4,04	A+	5,10	A+++
		OU NEXYA S4 E + IU CASSETTE NEXYA														
OUTDOOR UNIT	QUADRI SPLIT 28	OS-CEMYH28EI														
INDOOR UNIT	CASSETTE 9/12/18	OS-SANCH09EI / OS-SANCH12EI / OS-SANCH18EI														

Available combinations														
Cooling		Cooling capacity							Power input			EER (W/W)	SEER	Energy Class
	UI combinations	Each room (kW)				Total (kW)			(kW)					
		A	B	C	D	min	nominal	max	min	rating	max			
1 units	18	5,00	—	—	—	1,74	5,00	6,50	0,50	1,55	1,78	3,23	—	—
2 units	9+9	2,65	2,65	—	—	2,08	5,30	6,89	0,64	1,64	2,31	3,23	5,1	A
	9+12	2,57	3,43	—	—	2,08	6,00	7,06	0,64	1,86	2,44	3,23	5,10	A
	9+18	2,43	4,87	—	—	2,08	7,30	7,64	0,64	2,26	2,83	3,23	5,10	A
	12+12	3,25	3,25	—	—	2,08	6,50	7,47	0,64	2,01	2,52	3,23	5,10	A
	12+18	2,92	4,38	—	—	2,08	7,30	7,64	0,64	2,26	2,83	3,23	5,10	A
3 units	9+9+9	2,37	2,37	2,37	—	2,66	7,10	8,55	0,77	2,20	2,98	3,23	6,5	A++
	9+9+12	2,34	2,34	3,12	—	2,66	7,80	8,55	0,77	2,41	2,98	3,23	6,50	A++
	9+9+18	1,95	1,95	3,90	—	2,66	7,80	8,55	0,77	2,41	2,98	3,23	6,50	A++
	9+12+12	2,13	2,84	2,84	—	2,66	7,80	8,55	0,77	2,41	2,98	3,23	6,50	A++
	12+12+12	2,60	2,60	2,60	—	2,66	7,80	8,55	0,77	2,41	2,98	3,23	6,50	A++
4 units	9+9+9+9	2,08	2,08	2,08	2,08	2,91	8,30	10,04	0,87	2,57	3,21	3,23	6,8	A++
	9+9+9+12	1,89	1,89	1,89	2,32	2,79	7,98	9,65	0,74	2,17	2,71	3,67	6,77	A++

Available combinations																
Heating		Heating capacity							Power input			COP (W/W)	SCOP Average Season	Energy Class Average Season	SCOP Warmer Season	Energy Class Warmer
	UI combinations	Each room (kW)				Total (kW)			(kW)							
		A	B	C	D	min	nominal	max	min	rating	max					
1 units	18	5,60	—	—	—	1,85	5,60	6,77	0,50	1,48	1,70	3,78	—	—	—	—
2 units	9+9	3,00	3,00	—	—	2,20	6,00	7,30	0,59	1,57	2,13	3,81	3,4	A	—	—
	9+12	3,00	4,00	—	—	2,20	7,00	7,47	0,59	1,84	2,25	3,81	3,4	A	—	—
	9+18	2,63	5,27	—	—	2,20	7,90	8,09	0,59	2,05	2,61	3,85	3,4	A	—	—
	12+12	3,75	3,75	—	—	2,20	7,50	7,91	0,59	1,97	2,32	3,81	3,4	A	—	—
	12+18	3,20	4,80	—	—	2,20	8,00	8,09	0,59	2,08	2,61	3,85	3,4	A	—	—
3 units	9+9+9	2,87	2,87	2,87	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,5	A	—	—
	9+9+12	2,58	2,58	3,44	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,5	A	—	—
	9+9+18	2,15	2,15	4,30	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,5	A	—	—
	9+12+12	2,35	3,13	3,13	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,5	A	—	—
	12+12+12	2,87	2,87	2,87	—	2,81	8,60	9,06	0,71	2,32	2,75	3,71	3,5	A	—	—
4 units	9+9+9+9	2,20	2,20	2,20	2,20	3,08	8,79	10,64	0,81	2,37	2,96	3,71	4,0	A+	—	—
	9+9+9+12	1,87	1,87	1,87	2,50	2,84	8,12	9,82	0,68	2,01	2,52	4,03	3,96	A	5,06	A++

MULTISPLIT PENTA 42

		OU NEXYA S5 E + IU WALL NEXYA S5													
OUTDOOR UNIT	PENTA SPLIT 42	OS-CANMH42EI													
INDOOR UNIT	WALL 9 / 12 / 18/24	OS-SANQH09EI / OS-SANQH12EI/ OS-SANQH18EI// OS-SANQH24EI													
Available combinations															
Cooling		Cooling capacity								Power input			EER (W/W)	SEER	Energy Class
	UI combinations	Each room (kW)					Total (kW)			(kW)					
		A	B	C	D	E	min	nominal	max	min	rating	max			
2 units	9+12	2,58	3,44	—	—	—	1,81	6,02	6,62	0,24	1,61	1,94	3,73	7,07	A++
	9+18	2,65	5,31	—	—	—	2,39	7,96	8,75	0,34	2,27	2,72	3,51	7,14	A++
	12+12	3,50	3,50	—	—	—	2,10	7,00	7,70	0,29	1,96	2,35	3,58	7,04	A++
	12+18	3,52	5,28	—	—	—	2,64	8,80	9,67	0,40	2,64	3,17	3,33	7,02	A++
	18+18	6,12	6,12	—	—	—	3,67	12,25	13,47	0,70	4,69	5,62	2,61	6,55	A++
	18+24	4,30	5,73	—	—	—	3,01	10,03	11,03	0,47	3,11	3,73	3,23	6,45	A++
3 units	9+9+9	2,61	2,61	2,61	—	—	2,35	7,82	8,60	0,31	2,06	2,47	3,80	7,40	A++
	9+9+12	2,61	2,61	3,49	—	—	2,61	8,71	9,59	0,36	2,39	2,86	3,65	7,34	A++
	9+9+18	2,63	2,63	5,25	—	—	3,15	10,51	11,56	0,46	3,09	3,71	3,40	7,24	A++
	9+12+12	2,64	3,51	3,51	—	—	2,90	9,66	10,63	0,42	2,79	3,34	3,47	7,17	A++
	9+12+18	2,63	3,51	5,26	—	—	3,42	11,40	12,54	0,53	3,55	4,26	3,21	7,09	A++
	9+18+18	2,45	4,91	4,91	—	—	3,68	12,27	13,50	0,61	4,04	4,85	3,04	6,90	A++
	9+18+24	1,99	3,97	5,29	—	—	3,38	11,25	12,70	0,52	3,48	4,29	3,23	6,68	A++
	12+12+12	3,50	3,50	3,50	—	—	3,15	10,50	11,55	0,48	3,20	3,84	3,28	7,04	A++
	12+12+18	3,52	3,52	5,27	—	—	3,69	12,30	13,53	0,62	4,14	4,97	2,97	7,03	A++
	12+18+18	3,07	4,60	4,60	—	—	3,68	12,28	13,50	0,61	4,05	4,86	3,03	6,91	A++
12+18+24	2,58	3,87	5,16	—	—	3,49	11,62	12,78	0,54	3,60	4,32	3,23	6,80	A++	

4 units	9+9+9+9	2,59	2,59	2,59	2,59	—	3,11	10,36	11,40	0,44	2,92	3,50	3,55	7,28	A++		
	9+9+9+12	2,61	2,61	2,61	3,48	—	3,40	11,32	12,46	0,50	3,36	4,04	3,37	7,15	A++		
	9+9+9+18	2,46	2,46	2,46	4,92	—	3,69	12,30	13,53	0,58	3,88	4,66	3,17	7,17	A++		
	9+9+12+12	2,63	2,63	3,51	3,51	—	3,68	12,27	13,50	0,58	3,86	4,64	3,18	7,14	A++		
	9+9+12+18	2,31	2,31	3,08	4,62	—	3,69	12,31	13,54	0,58	3,88	4,66	3,17	7,19	A++		
	9+12+12+12	2,45	3,27	3,27	3,27	—	3,68	12,27	13,50	0,58	3,87	4,64	3,17	7,15	A++		
	9+12+12+18	2,17	2,90	2,90	4,35	—	3,70	12,32	13,56	0,58	3,88	4,66	3,17	7,20	A++		
	12+12+12+12	3,07	3,07	3,07	3,07	—	3,68	12,28	13,50	0,58	3,88	4,65	3,17	7,15	A++		
	12+12+12+18	2,72	2,72	2,72	4,08	—	3,67	12,25	13,47	0,57	3,78	4,54	3,24	7,21	A++		
5 units	9+9+9+9+9	2,46	2,46	2,46	2,46	2,46	3,69	12,31	13,10	0,57	3,75	4,49	3,28	7,30	A++		
	9+9+9+9+12	2,31	2,31	2,31	2,31	3,08	3,70	12,32	13,55	0,56	3,75	4,50	3,28	7,31	A++		
	9+9+9+9+18	2,05	2,05	2,05	2,05	4,11	3,70	12,33	13,56	0,56	3,74	4,48	3,30	7,33	A++		
	9+9+9+12+12	2,18	2,18	2,18	2,90	2,90	3,70	12,33	13,56	0,56	3,75	4,51	3,28	7,32	A++		
	9+9+9+12+18	1,95	1,95	1,95	2,60	3,90	3,70	12,34	13,57	0,56	3,74	4,48	3,30	7,34	A++		
	9+9+12+12+12	2,06	2,06	2,74	2,74	2,74	3,70	12,34	13,57	0,56	3,76	4,51	3,29	7,33	A++		
	9+9+12+12+18	1,85	1,85	2,47	2,47	3,70	3,70	12,35	13,58	0,56	3,74	4,48	3,30	7,35	A++		
	9+12+12+12+12	1,95	2,60	2,60	2,60	2,60	3,70	12,35	13,58	0,56	3,76	4,51	3,29	7,34	A++		
	9+12+12+12+18	1,76	2,35	2,35	2,35	3,53	3,71	12,35	13,59	0,56	3,74	4,48	3,31	7,36	A++		
	12+12+12+12+12	2,47	2,47	2,47	2,47	2,47	3,71	12,36	13,59	0,56	3,76	4,51	3,29	7,34	A++		
	12+12+12+12+18	2,25	2,25	2,25	2,25	3,37	3,71	12,36	13,60	0,56	3,74	4,49	3,31	7,37	A++		
Available combinations																	
Heating		Heating capacity								Power input			COP (W/W)	SCOP Average Season	Energy Class Average	SCOP Warmer Season	Energy Class Warmer Season
	UI combinations	Each room (kW)					Total (kW)			(kW)							
		A	B	C	D	E	min	nominal	max	min	rating	max					
2 units	9+12	2,68	3,57	—	—	—	1,87	6,25	6,87	0,29	1,93	2,32	3,24	3,55	A	4,72	A++
	9+18	2,73	5,47	—	—	—	2,46	8,20	9,02	0,36	2,41	2,89	3,40	3,77	A	4,86	A++
	12+12	3,60	3,60	—	—	—	2,16	7,20	7,92	0,35	2,35	2,82	3,06	3,54	A	4,59	A+
	12+18	3,65	5,47	—	—	—	2,74	9,12	10,04	0,42	2,80	3,36	3,25	3,76	A	4,83	A++
	18+18	6,17	6,17	—	—	—	3,70	12,34	13,58	0,60	3,97	4,76	3,11	3,86	A	4,98	A++
3 units	18+24	3,97	5,30	—	—	—	2,78	9,27	11,38	0,37	2,50	3,35	3,71	3,36	B	4,64	A++
	9+9+9	2,68	2,68	2,68	—	—	2,42	8,05	8,86	0,35	2,33	2,79	3,46	3,76	A	4,99	A++
	9+9+12	2,70	2,70	3,60	—	—	2,70	8,99	9,89	0,41	2,71	3,25	3,32	3,74	A	4,94	A++
	9+9+18	2,72	2,72	5,44	—	—	3,26	10,87	11,96	0,49	3,23	3,88	3,36	3,86	A	4,99	A++
	9+12+12	2,71	3,61	3,61	—	—	2,98	9,93	10,92	0,47	3,14	3,76	3,17	3,72	A	4,90	A++
	9+12+18	2,70	3,60	5,39	—	—	3,51	11,69	12,85	0,54	3,59	4,31	3,25	3,84	A	4,96	A++
	9+18+18	2,46	4,91	4,91	—	—	3,68	12,28	13,51	0,54	3,59	4,31	3,42	3,92	A	5,20	A+++
	9+18+24	1,85	3,70	4,94	—	—	3,15	10,49	12,45	0,42	2,83	3,66	3,71	3,55	A	4,92	A++
	12+12+12	3,58	3,58	3,58	—	—	3,22	10,74	11,81	0,53	3,53	4,23	3,05	3,70	A	4,86	A++
	12+12+18	3,53	3,53	5,29	—	—	3,70	12,35	13,58	0,59	3,90	4,68	3,16	3,83	A	4,92	A++
	12+18+18	3,07	4,61	4,61	—	—	3,69	12,29	13,52	0,54	3,59	4,30	3,43	3,92	A	5,20	A+++
4 units	12+18+24	2,39	3,58	4,78	—	—	3,23	10,75	12,50	0,43	2,90	3,68	3,71	3,60	A	4,86	A++
	9+9+9+9	2,68	2,68	2,68	2,68	—	3,22	10,72	11,80	0,50	3,34	4,01	3,21	3,75	A	4,96	A++
	9+9+9+12	2,69	2,69	2,69	3,59	—	3,50	11,66	12,83	0,57	3,78	4,53	3,09	3,73	A	4,93	A++
	9+9+9+18	2,46	2,46	2,46	4,93	—	3,70	12,32	13,55	0,56	3,71	4,45	3,32	3,82	A	5,00	A++
	9+9+12+12	2,64	2,64	3,52	3,52	—	3,69	12,32	13,55	0,61	4,09	4,91	3,01	3,73	A	4,94	A++
	9+9+12+18	2,31	2,31	3,08	4,62	—	3,70	12,32	13,55	0,56	3,71	4,46	3,32	3,83	A	5,01	A++
	9+12+12+12	2,47	3,29	3,29	3,29	—	3,70	12,33	13,56	0,61	4,08	4,89	3,02	3,74	A	4,96	A++
	9+12+12+18	2,17	2,90	2,90	4,35	—	3,70	12,32	13,55	0,56	3,71	4,45	3,32	3,83	A	5,02	A++
	12+12+12+12	3,09	3,09	3,09	3,09	—	3,70	12,34	13,57	0,61	4,06	4,88	3,04	3,74	A	4,97	A++
	12+12+12+18	2,74	2,74	2,74	4,11	—	3,70	12,33	13,56	0,55	3,70	4,44	3,33	3,84	A	5,03	A++
	5 units	9+9+9+9+9	2,36	2,36	2,36	2,36	2,36	3,69	12,28	12,30	0,52	3,28	3,92	3,74	3,90	A	5,10
9+9+9+9+12		2,21	2,21	2,21	2,21	2,95	3,54	11,81	12,99	0,48	3,18	3,82	3,71	3,90	A	5,09	A++
9+9+9+9+18		2,05	2,05	2,05	2,05	4,11	3,70	12,33	13,56	0,49	3,29	3,95	3,75	3,92	A	5,21	A+++
9+9+9+12+12		2,09	2,09	2,09	2,79	2,79	3,55	11,84	13,03	0,48	3,19	3,83	3,71	3,91	A	5,09	A++
9+9+9+12+18		1,95	1,95	1,95	2,60	3,89	3,70	12,33	13,56	0,49	3,29	3,94	3,75	3,93	A	5,21	A+++
9+9+12+12+12		1,98	1,98	2,64	2,64	2,64	3,56	11,88	13,06	0,48	3,20	3,84	3,71	3,91	A	5,09	A++
9+9+12+12+18		1,85	1,85	2,47	2,47	3,70	3,70	12,33	13,57	0,49	3,28	3,94	3,76	3,93	A	5,21	A+++
9+12+12+12+12		1,88	2,51	2,51	2,51	2,51	3,57	11,91	13,10	0,48	3,21	3,85	3,71	3,92	A	5,09	A++
9+12+12+12+18		1,76	2,35	2,35	2,35	3,53	3,70	12,34	13,57	0,49	3,28	3,94	3,76	3,93	A	5,21	A+++
12+12+12+12+12		2,39	2,39	2,39	2,39	2,39	3,58	11,94	13,13	0,48	3,22	3,86	3,71	3,92	A	5,09	A++
12+12+12+12+18		2,24	2,24	2,24	2,24	3,37	3,70	12,34	13,58	0,49	3,28	3,93	3,77	3,94	A	5,21	A+++
		OU NEXYA SS E + IU WALL NEXYA															
OUTDOOR UNIT	PENTA SPLIT 42	OS-CANMH42EI															
INDOOR UNIT	WALL 9 / 12 / 18	OS-SENEH09EI / OS-SENEH12EI / OS-SENEH18EI															
Available combinations																	
Cooling		Cooling capacity								Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)					Total (kW)			(kW)							
		A	B	C	D	E	min	nominal	max								

		9+9+12+12+12	2,05	2,05	2,73	2,73	2,73	4,18	12,83	14,00	1,03	3,98	4,57	3,23	6,57	A++			
Available combinations																			
Heating			Heating capacity									Power input			COP (W/W)	SCOP Average Season	Energy Class Average	SCOP Warmer Season	Energy Class Warmer Season
	UI combinations	Each room (kW)					Total (kW)			(kW)									
		A	B	C	D	E	min	nominal	max	min	rating	max							
2 units	9+12	2,91	3,89	—	—	—	2,34	6,80	8,61	0,56	1,79	2,25	3,80	3,00	C	—	—		
	9+18	2,93	5,87	—	—	—	2,34	8,80	11,07	0,56	2,32	2,49	3,80	3,00	C	—	—		
	12+12	3,75	3,75	—	—	—	2,34	7,50	9,23	0,56	1,97	2,35	3,80	3,00	C	—	—		
	12+18	3,76	5,64	—	—	—	2,34	9,40	11,69	0,56	2,47	2,72	3,80	3,00	C	—	—		
3 units	9+9+9	3,33	3,33	3,33	—	—	2,89	10,00	12,30	0,70	2,60	3,32	3,85	3,20	B	—	—		
	9+9+12	3,30	3,30	4,40	—	—	2,89	11,00	12,30	0,70	2,86	3,15	3,85	3,20	B	—	—		
	9+9+18	2,88	2,88	5,75	—	—	2,89	11,50	12,30	0,70	2,99	3,32	3,85	3,20	B	—	—		
	9+12+12	3,14	4,18	4,18	—	—	2,89	11,50	12,30	0,70	2,99	3,15	3,85	3,20	B	—	—		
	9+12+18	2,77	3,69	5,54	—	—	2,89	12,00	12,92	0,70	3,12	3,32	3,85	3,20	B	—	—		
	12+12+12	3,83	3,83	3,83	—	—	2,89	11,50	12,30	0,70	2,99	3,25	3,85	3,20	B	—	—		
	12+12+18	3,43	3,43	5,14	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,85	3,20	B	—	—		
4 units	9+9+9+9	3,00	3,00	3,00	3,00	—	3,69	12,00	13,53	0,80	3,07	3,65	3,91	3,40	A	—	—		
	9+9+9+12	2,77	2,77	2,77	3,69	—	3,69	12,00	13,53	0,80	3,07	3,65	3,91	3,40	A	—	—		
	9+9+9+18	2,40	2,40	2,40	4,80	—	3,69	12,00	13,53	0,80	3,07	3,81	3,91	3,40	A	—	—		
	9+9+12+12	2,57	2,57	3,43	3,43	—	3,69	12,00	13,53	0,80	3,07	3,65	3,91	3,40	A	—	—		
	9+9+12+18	2,25	2,25	3,00	4,50	—	3,69	12,00	13,53	0,80	3,07	3,81	3,91	3,40	A	—	—		
	9+12+12+12	2,40	3,20	3,20	3,20	—	3,69	12,00	13,53	0,80	3,07	3,65	3,91	3,40	A	—	—		
	9+12+12+18	2,12	2,82	2,82	4,24	—	3,69	12,00	13,53	0,80	3,07	3,81	3,91	3,40	A	—	—		
	12+12+12+12	3,00	3,00	3,00	3,00	—	3,69	12,00	13,53	0,80	3,07	3,65	3,91	3,40	A	—	—		
	12+12+12+18	2,67	2,67	2,67	4,00	—	3,69	12,00	13,53	0,80	3,07	3,81	3,91	3,40	A	—	—		
5 units	9+9+9+9+9	2,46	2,46	2,46	2,46	2,46	4,18	12,30	14,94	0,90	3,32	4,14	3,71	3,50	A	5,10	A+++		
	9+9+9+9+12	2,31	2,31	2,31	2,31	3,08	4,18	12,77	14,94	0,90	3,34	4,14	3,83	3,68	A	4,91	A++		
	9+9+9+9+18	2,05	2,05	2,05	2,05	4,10	4,18	12,81	14,94	0,90	3,28	4,14	3,90	3,65	A	4,97	A++		
	9+9+9+12+12	2,17	2,17	2,17	2,89	2,89	4,18	12,85	14,94	0,90	3,32	4,14	3,88	3,72	A	4,96	A++		
	9+9+9+12+18	1,94	1,94	1,94	2,59	3,88	4,18	12,89	14,94	0,90	3,26	4,14	3,95	3,68	A	5,01	A++		
	9+9+12+12+12	2,05	2,05	2,73	2,73	2,73	4,18	12,91	14,94	0,90	3,32	4,14	3,89	3,73	A	5,01	A++		
			OU NEXYA S5 E + IU DUCT S6 NEXYA																
OUTDOOR UNIT	PENTA SPLIT 42		OS-CANMH42EI																
INDOOR UNIT	DUCT 9/12/18		OS-SEDAH09EI/OS-SEDAH12EI/OS-SEDAH18EI																
Available combinations																			
Cooling			Cooling capacity									Power input			EER (W/W)	SEER	Energy Class		
	UI combinations	Each room (kW)					Total (kW)			(kW)									
		A	B	C	D	E	min	nominal	max	min	rating	max							
2 units	9+12	2,60	3,46	—	—	—	1,82	6,06	6,67	0,27	1,77	2,13	3,42	5,92	A+				
	9+18	2,64	5,28	—	—	—	2,38	7,93	8,72	0,36	2,42	2,90	3,28	6,04	A+				
	12+12	3,52	3,52	—	—	—	2,11	7,05	7,75	0,33	2,18	2,61	3,24	5,89	A+				
	12+18	3,52	5,29	—	—	—	2,64	8,81	9,69	0,43	2,86	3,44	3,08	5,92	A+				
3 units	9+9+9	2,61	2,61	2,61	—	—	2,35	7,84	8,62	0,34	2,24	2,69	3,50	6,15	A++				
	9+9+12	2,60	2,60	3,46	—	—	2,60	8,66	9,52	0,39	2,58	3,10	3,35	6,10	A++				
	9+9+18	2,62	2,62	5,24	—	—	3,15	10,49	11,53	0,51	3,40	4,08	3,08	5,95	A+				
	9+12+12	2,62	3,50	3,50	—	—	2,89	9,62	10,58	0,46	3,05	3,66	3,15	5,95	A+				
	9+12+18	2,63	3,51	5,26	—	—	3,42	11,39	12,53	0,59	3,96	4,75	2,88	5,83	A+				
	12+12+12	3,50	3,50	3,50	—	—	3,15	10,50	11,55	0,53	3,56	4,28	2,95	5,83	A+				
	12+12+18	3,51	3,51	5,27	—	—	3,69	12,29	13,52	0,70	4,64	5,56	2,65	5,76	A+				
4 units	9+9+9+9	2,60	2,60	2,60	2,60	—	3,12	10,41	11,45	0,48	3,21	3,85	3,25	6,01	A+				
	9+9+9+12	2,61	2,61	2,61	3,48	—	3,39	11,31	12,44	0,55	3,68	4,42	3,07	5,92	A+				
	9+9+9+18	2,46	2,46	2,46	4,91	—	3,68	12,28	13,51	0,63	4,19	5,03	2,93	6,05	A+				
	9+9+12+12	2,65	2,65	3,53	3,53	—	3,70	12,34	13,58	0,66	4,37	5,25	2,82	5,98	A+				
	9+9+12+18	2,30	2,30	3,07	4,61	—	3,69	12,29	13,52	0,63	4,20	5,04	2,93	6,05	A+				
	9+12+12+12	2,45	3,26	3,26	3,26	—	3,67	12,24	13,47	0,65	4,30	5,16	2,85	5,98	A+				
	9+12+12+18	2,17	2,89	2,89	4,34	—	3,69	12,30	13,53	0,63	4,20	5,04	2,93	6,05	A+				
	12+12+12+12	3,06	3,06	3,06	3,06	—	3,68	12,25	13,48	0,65	4,30	5,16	2,85	5,98	A+				
	12+12+12+18	2,73	2,73	2,73	4,10	—	3,69	12,30	13,53	0,63	4,20	5,04	2,93	6,04	A+				
5 units	9+9+9+9+9	2,46	2,46	2,46	2,46	2,46	3,69	12,31	13,54	0,62	4,10	4,92	3,00	6,10	A++				
	9+9+9+9+12	2,31	2,31	2,31	2,31	3,08	3,69	12,32	13,55	0,62	4,10	4,93	3,00	6,10	A++				
	9+9+9+9+18	2,06	2,06	2,06	2,06	4,12	3,70	12,35	13,58	0,61	4,06	4,87	3,04	6,13	A++				
	9+9+9+12+12	2,17	2,17	2,17	2,90	2,90	3,70	12,32	13,55	0,62	4,11	4,93	3,00	6,10	A++				
	9+9+9+12+18	1,95	1,95	1,95	2,60	3,90	3,71	12,35	13,59	0,61	4,06	4,87	3,04	6,13	A++				
	9+9+12+12+12	2,05	2,05	2,74	2,74	2,74	3,70	12,33	13,56	0,62	4,11	4,93	3,00	6,10	A++				
Available combinations																			
Heating			Heating capacity									Power input			COP (W/W)	SCOP Average Season	Energy Class Average	SCOP Warmer Season	Energy Class Warmer Season
	UI combinations	Each room (kW)					Total (kW)			(kW)									
		A	B	C	D	E	min	nominal	max	min	rating	max							
2 units	9+12	2,65	3,54	—	—	—	1,86	6,19	6,81	0,26	1,75	2,09	3,55	3,28	B	4,21	A+		
	9+18	2,71	5,41	—	—	—	2,44	8,12	8,93	0,36	2,43	2,92	3,34	3,27	B	4,20	A+		
	12+12	3,60	3,60	—	—	—	2,16	7,20	7,92	0,32	2,15	2,58	3,35	3,25	B	4,13	A+		
	12+18	3,62	5,43	—	—	—	2,71	9,05	9,95	0,43	2,85	3,42	3,17	3,25	B	4,08	A+		
3 units	9+9+9	2,68	2,68	2,68	—	—	2,41	8,05	8,85	0,32	2,13	2,55	3,79	3,47	A	4,49	A+		
	9+9+12	2,67	2,67	3,56	—	—	2,67	8,89	9,78	0,37	2,44	2,93	3,65	3,47	A	4,43	A+		
	9+9+18	2,68	2,68	5,37	—	—	3,22	10,74	11,81	0,47	3,14	3,77	3,42	3,42	A	4,34	A+		
	9+12+12	2,68	3,58	3,58	—	—	2,95	9,84	10,82	0,42	2,82	3,39	3,49	3,45	A	4,33	A+		
	9+12+18	2,70	3,60	5,40	—	—	3,51	11,6											

	9+9+12+12+12	2,05	2,05	2,74	2,74	2,74	3,69	12,32	13,55	0,49	3,29	3,95	3,74	3,60	A	4,60	A++												
		OU NEXYA 55 E + IU DUCT NEXYA																											
OUTDOOR UNIT	PENTA SPLIT 42	OS-CANMH42EI																											
INDOOR UNIT	DUCT 9/12/18	OS-SANDH09EI / OS-SANDH12EI / OS-SANDH18EI																											
Available combinations																													
Cooling		Cooling capacity								Power input			EER (W/W)	SEER	Energy Class														
	UI combinations	Each room (kW)					Total (kW)			(kW)																			
		A	B	C	D	E	min	nominal	max	min	rating	max																	
2 units	9+12	2,67	3,56	—	—	—	2,34	6,23	8,61	0,70	2,05	2,79	3,00	5,10	A														
	9+18	2,65	5,31	—	—	—	2,34	7,96	11,07	0,70	2,63	3,08	3,00	5,10	A														
	12+12	3,55	3,55	—	—	—	2,34	7,09	9,23	0,70	2,34	2,91	3,00	5,10	A														
	12+18	3,53	5,30	—	—	—	2,34	8,83	11,69	0,70	2,91	3,36	3,00	5,10	A														
3 units	9+9+9	2,62	2,62	2,62	—	—	2,89	7,86	10,46	0,86	2,10	4,10	3,00	5,30	A														
	9+9+12	2,62	2,62	3,49	—	—	2,89	8,73	12,92	0,86	2,33	3,90	3,00	5,30	A														
	9+9+18	2,62	2,62	5,23	—	—	2,89	10,47	12,30	0,86	2,80	4,10	3,00	5,30	A														
	9+12+12	2,62	3,49	3,49	—	—	2,89	9,60	11,07	0,86	2,56	3,90	3,00	5,30	A														
	9+12+18	2,62	3,49	5,23	—	—	2,89	11,34	11,69	0,86	3,03	4,10	3,00	5,30	A														
	12+12+12	3,49	3,49	3,49	—	—	2,89	10,47	11,07	0,86	2,80	4,02	3,00	5,30	A														
	12+12+18	3,49	3,49	5,23	—	—	2,89	12,20	12,92	0,86	3,26	4,26	3,00	5,30	A														
4 units	9+9+9+9	2,63	2,63	2,63	2,63	—	3,69	10,50	12,92	0,98	3,50	4,51	3,00	5,60	A+														
	9+9+9+12	2,65	2,65	2,65	3,54	—	3,69	11,50	13,53	0,98	3,83	4,51	3,00	5,60	A+														
	9+9+9+18	2,40	2,40	2,40	4,80	—	3,69	12,00	13,53	0,98	4,00	4,72	3,00	5,60	A+														
	9+9+12+12	2,46	2,46	3,29	3,29	—	3,69	11,50	13,53	0,98	3,83	4,51	3,00	5,60	A+														
	9+9+12+18	2,25	2,25	3,00	4,50	—	3,69	12,00	13,53	0,98	4,00	4,72	3,00	5,60	A+														
	9+12+12+12	2,30	3,07	3,07	3,07	—	3,69	11,50	13,53	0,98	3,83	4,51	3,00	5,60	A+														
	9+12+12+18	2,17	2,89	2,89	4,34	—	3,69	12,30	13,53	0,98	4,10	4,72	3,00	5,60	A+														
	12+12+12+12	2,88	2,88	2,88	2,88	—	3,69	11,50	13,53	0,98	3,83	4,51	3,00	5,60	A+														
5 units	12+12+12+18	2,73	2,73	2,73	4,10	—	3,69	12,30	13,53	0,98	4,10	4,72	3,00	5,60	A+														
	9+9+9+9+9	2,46	2,46	2,46	2,46	2,46	4,18	12,30	14,00	1,11	4,10	4,92	3,00	6,10	A++														
	9+9+9+9+12	2,31	2,31	2,31	2,31	3,08	4,18	12,92	14,00	1,11	4,16	4,92	3,10	5,89	A+														
	9+9+9+9+18	2,05	2,05	2,05	2,05	4,10	4,18	12,52	14,00	1,11	3,85	4,92	3,25	5,81	A+														
	9+9+9+12+12	2,17	2,17	2,17	2,89	2,89	4,18	12,47	14,00	1,11	3,85	4,92	3,24	6,03	A+														
	9+9+9+12+18	1,94	1,94	1,94	2,59	3,88	4,18	12,63	14,00	1,11	3,87	4,92	3,27	5,89	A+														
9+9+12+12+12	2,05	2,05	2,73	2,73	2,73	4,18	12,59	14,00	1,11	3,86	4,92	3,26	6,17	A++															
Available combinations																													
Heating		Heating capacity								Power input			COP (W/W)	SCOP Average Season	Energy Class Average	SCOP Warmer Season	Energy Class Warmer Season												
	UI combinations	Each room (kW)					Total (kW)			(kW)																			
		A	B	C	D	E	min	nominal	max	min	rating	max																	
2 units	9+12	2,91	3,89	—	—	—	2,34	6,80	8,62	0,56	1,83	2,26	3,71	3,00	C	—	—												
	9+18	2,93	5,87	—	—	—	2,34	8,80	11,08	0,56	2,37	2,49	3,71	3,00	C	—	—												
	12+12	3,75	3,75	—	—	—	2,34	7,50	9,23	0,56	2,02	2,36	3,71	3,00	C	—	—												
	12+18	3,76	5,64	—	—	—	2,34	9,40	11,69	0,56	2,53	2,72	3,71	3,00	C	—	—												
3 units	9+9+9	3,33	3,33	3,33	—	—	2,89	10,00	12,31	0,70	2,70	3,32	3,71	3,20	B	—	—												
	9+9+12	3,30	3,30	4,40	—	—	2,89	11,00	12,31	0,70	2,96	3,15	3,71	3,20	B	—	—												
	9+9+18	2,88	2,88	5,75	—	—	2,89	11,50	12,31	0,70	3,10	3,32	3,71	3,20	B	—	—												
	9+12+12	3,14	4,18	4,18	—	—	2,89	11,50	12,31	0,70	3,10	3,15	3,71	3,20	B	—	—												
	9+12+18	2,77	3,69	5,54	—	—	2,89	12,00	12,92	0,70	3,23	3,32	3,71	3,20	B	—	—												
	12+12+12	3,83	3,83	3,83	—	—	2,89	11,50	12,31	0,70	3,10	3,25	3,71	3,20	B	—	—												
	12+12+18	3,43	3,43	5,14	—	—	2,89	12,00	12,92	0,70	3,23	3,45	3,71	3,20	B	—	—												
4 units	9+9+9+9	3,00	3,00	3,00	3,00	—	3,69	12,00	13,54	0,80	3,23	3,65	3,71	3,40	A	—	—												
	9+9+9+12	2,77	2,77	2,77	3,69	—	3,69	12,00	13,54	0,80	3,23	3,65	3,71	3,40	A	—	—												
	9+9+9+18	2,40	2,40	2,40	4,80	—	3,69	12,00	13,54	0,80	3,23	3,82	3,71	3,40	A	—	—												
	9+9+12+12	2,57	2,57	3,43	3,43	—	3,69	12,00	13,54	0,80	3,23	3,65	3,71	3,40	A	—	—												
	9+9+12+18	2,25	2,25	3,00	4,50	—	3,69	12,00	13,54	0,80	3,23	3,82	3,71	3,40	A	—	—												
	9+12+12+12	2,40	3,20	3,20	3,20	—	3,69	12,00	13,54	0,80	3,23	3,65	3,71	3,40	A	—	—												
	9+12+12+18	2,12	2,82	2,82	4,24	—	3,69	12,00	13,54	0,80	3,23	3,82	3,71	3,40	A	—	—												
	12+12+12+12	3,00	3,00	3,00	3,00	—	3,69	12,00	13,54	0,80	3,23	3,65	3,71	3,40	A	—	—												
	12+12+12+18	2,67	2,67	2,67	4,00	—	3,69	12,00	13,54	0,80	3,23	3,82	3,71	3,40	A	—	—												
5 units	9+9+9+9+9	2,46	2,46	2,46	2,46	2,46	4,19	12,31	14,96	0,90	3,32	4,15	3,71	3,60	A	4,60	A++												
	9+9+9+9+12	2,31	2,31	2,31	2,31	3,08	4,19	13,45	14,96	0,90	3,19	4,15	4,22	3,96	A	4,91	A++												
	9+9+9+9+18	2,05	2,05	2,05	2,05	4,10	4,19	13,48	14,96	0,90	3,17	4,15	4,25	3,91	A	4,90	A++												
	9+9+9+12+12	2,17	2,17	2,17	2,90	2,90	4,19	13,45	14,96	0,90	3,18	4,15	4,22	3,96	A	4,90	A++												
	9+9+9+12+18	1,94	1,94	1,94	2,59	3,89	4,19	13,48	14,96	0,90	3,17	4,15	4,26	3,91	A	4,90	A++												
	9+9+12+12+12	2,05	2,05	2,74	2,74	2,74	4,19	13,45	14,96	0,90	3,18	4,15	4,23	3,96	A	4,90	A++												
		OU NEXYA 55 E + IU CASSETTE 56 NEXYA																											
OUTDOOR UNIT	PENTA SPLIT 42	OS-CANMH42EI																											
INDOOR UNIT	CASSETTE 9/12/18	OS-SENAH09EI/OS-SENAH12EI/OS-SENAH18EI																											
Available combinations																													
Cooling		Cooling capacity								Power input			EER (W/W)	SEER	Energy Class														
	UI combinations	Each room (kW)					Total (kW)			(kW)																			
		A	B	C	D	E	min	nominal	max	min	rating	max																	
2 units	9+12	2,58	3,44	—	—	—	1,81	6,02	6,62	0,27	1,79	2,14	3,37	5,90	A+														
	9+18	2,65	5,29	—	—	—	2,38	7,94	8,73	0,37	2,44	2,92	3,26	6,17	A++														
	12+12	3,51	3,51	—	—	—	2,11	7,03	7,73	0,32	2,13	2,56	3,30	6,02	A+														
	12+18	3,51	5,26	—	—	—	2,63	8,77	9,65	0,42	2,77	3,32	3,17	6,17	A++														
3 units	9+9+9	2,59	2,59	2,59	—	—	2,34	7,78	8,56	0,35	2,36	2,83	3,30	6,04	A+														
	9+9+12	2,59	2,59	3,45	—	—	2,59	8,64	9,50	0,40	2,69	3,22	3,21	6,07	A+														
	9+9+18	2,63	2,63	5,27	—	—	3,16	10,54	11,59	0,54	3,60	4,32	2,93	5,86	A+														
	9+12+12	2,61	3,48	3,48	—	—	2,87	9,56	10,51	0,46	3,10	3,72	3,09	6,06	A+														
	9+12+18	2,63	3,51	5,27	—	—	3,42	11,41	12,55	0,62	4,13	4,95	2,77	5,81	A+														
	12+12+12	3,50	3,50	3,50	—	—	3,15	10,49	11,54	0,53	3,56	4,28	2,94	5,91	A+														
	12+12+18	3,51	3,51	5,27	—	—	3,69	12,30	13,53	0,70	4,64	5,57	2,65	5,85	A+														
4 units	9+9+9+9	2,59	2,59	2,59	2,59	—	3,11	10,																					

5 units	9+9+9+9+18	2,06	2,06	2,06	2,06	4,12	3,70	12,35	13,58	0,64	4,26	5,11	2,90	5,87	A+											
	9+9+9+12+12	2,17	2,17	2,17	2,89	2,89	3,69	12,29	13,52	0,64	4,29	5,15	2,87	5,70	A+											
	9+9+9+12+18	1,94	1,94	1,94	2,59	3,89	3,69	12,31	13,54	0,63	4,18	5,02	2,94	5,72	A+											
	9+9+12+12+12	2,04	2,04	2,73	2,73	2,73	3,68	12,26	13,49	0,63	4,22	5,06	2,91	5,75	A+											
Available combinations																										
Heating		Heating capacity								Power input			COP (W/W)	SCOP Average Season	Energy Class Average	SCOP Warmer Season	Energy Class Warmer Season									
	UI combinations	Each room (kW)					Total (kW)			(kW)																
		A	B	C	D	E	min	nominal	max	min	rating	max														
2 units	9+12	2,63	3,51	—	—	—	1,84	6,14	6,75	0,26	1,75	2,10	3,51	3,45	A	4,43	A+									
	9+18	2,71	5,43	—	—	—	2,44	8,14	8,96	0,34	2,25	2,70	3,62	3,65	A	4,61	A++									
	12+12	3,57	3,57	—	—	—	2,14	7,15	7,86	0,30	2,01	2,42	3,55	3,53	A	4,55	A+									
	12+18	3,64	5,46	—	—	—	2,73	9,10	10,00	0,38	2,50	3,01	3,63	3,71	A	4,67	A++									
3 units	9+9+9	2,68	2,68	2,68	—	—	2,41	8,03	8,84	0,35	2,32	2,79	3,46	3,51	A	4,64	A++									
	9+9+12	2,66	2,66	3,55	—	—	2,66	8,87	9,75	0,38	2,51	3,01	3,53	3,61	A	4,71	A++									
	9+9+18	2,69	2,69	5,39	—	—	3,23	10,77	11,85	0,45	3,02	3,63	3,56	3,76	A	4,80	A++									
	9+12+12	2,67	3,56	3,56	—	—	2,94	9,80	10,78	0,41	2,77	3,32	3,54	3,70	A	4,75	A++									
	9+12+18	2,70	3,61	5,41	—	—	3,52	11,72	12,89	0,50	3,32	3,98	3,53	3,79	A	4,88	A++									
	12+12+12	3,59	3,59	3,59	—	—	3,23	10,76	11,84	0,46	3,05	3,67	3,52	3,52	A	4,84	A++									
	12+12+18	3,49	3,49	5,24	—	—	3,67	12,23	13,45	0,51	3,42	4,10	3,57	3,82	A	4,97	A++									
4 units	9+9+9+9	2,67	2,67	2,67	2,67	—	3,20	10,68	11,75	0,46	3,09	3,71	3,46	3,64	A	4,83	A++									
	9+9+9+12	2,65	2,65	2,65	3,54	—	3,45	11,49	12,64	0,50	3,32	3,98	3,46	3,70	A	4,95	A++									
	9+9+9+18	2,45	2,45	2,45	4,90	—	3,67	12,25	13,47	0,51	3,37	4,05	3,63	3,81	A	5,05	A++									
	9+9+12+12	2,63	2,63	3,51	3,51	—	3,69	12,29	13,52	0,53	3,55	4,26	3,47	3,76	A	5,02	A++									
	9+9+12+18	2,31	2,31	3,08	4,62	—	3,70	12,32	13,56	0,50	3,31	3,97	3,72	3,86	A	5,10	A+++									
	9+12+12+12	2,45	3,26	3,26	3,26	—	3,67	12,24	13,46	0,51	3,41	4,09	3,59	3,69	A	5,08	A++									
	9+12+12+18	2,16	2,88	2,88	4,32	—	3,67	12,25	13,47	0,48	3,20	3,84	3,83	3,85	A	5,16	A+++									
5 units	12+12+12+12	3,08	3,08	3,08	3,08	—	3,69	12,31	13,54	0,50	3,34	4,01	3,69	3,69	A	5,13	A+++									
	12+12+12+18	2,73	2,73	2,73	4,10	—	3,69	12,30	13,53	0,47	3,15	3,78	3,90	3,85	A	5,18	A+++									
	9+9+9+9+9	2,46	2,46	2,46	2,46	2,46	3,69	12,31	13,54	0,52	3,50	4,20	3,52	3,80	A	5,10	A+++									
	9+9+9+9+12	2,30	2,30	2,30	2,30	3,06	3,68	12,25	13,48	0,50	3,36	4,04	3,64	3,82	A	5,16	A+++									
	9+9+9+9+18	2,04	2,04	2,04	2,04	4,08	3,68	12,25	13,48	0,48	3,17	3,80	3,86	3,88	A	5,22	A+++									
	9+9+9+12+12	2,17	2,17	2,17	2,90	2,90	3,70	12,32	13,56	0,50	3,30	3,96	3,73	3,86	A	5,22	A+++									
	9+9+9+12+18	1,94	1,94	1,94	2,59	3,89	3,69	12,31	13,54	0,47	3,12	3,75	3,95	3,91	A	5,24	A+++									
9+9+12+12+12	2,04	2,04	2,72	2,72	2,72	3,67	12,25	13,47	0,48	3,20	3,84	3,83	3,84	A	5,25	A+++										
		OU NEXYA SS E + IU CASSETTE NEXYA																								
OUTDOOR UNIT	PENTA SPLIT 42	OS-CANMH42EI																								
INDOOR UNIT	CASSETTE 9/12/18	OS-SANCH09EI / OS-SANCH12EI / OS-SANCH18EI																								
Available combinations																										
Cooling		Cooling capacity								Power input			EER (W/W)	SEER	Energy Class											
	UI combinations	Each room (kW)					Total (kW)			(kW)																
		A	B	C	D	E	min	nominal	max	min	rating	max														
2 units	9+12	2,67	3,56	—	—	—	2,34	6,23	8,61	0,65	2,21	2,59	3,10	5,10	A											
	9+18	2,65	5,31	—	—	—	2,34	7,96	11,07	0,65	2,83	2,86	3,04	5,10	A											
	12+12	3,55	3,55	—	—	—	2,34	7,09	9,23	0,65	2,52	2,70	3,07	5,10	A											
	12+18	3,53	5,30	—	—	—	2,34	8,83	11,69	0,65	3,14	3,12	3,02	5,10	A											
3 units	9+9+9	2,62	2,62	2,62	—	—	2,89	7,86	10,46	0,80	2,26	3,81	3,05	5,30	A											
	9+9+12	2,62	2,62	3,49	—	—	2,89	8,73	12,92	0,80	2,51	3,62	3,02	5,30	A											
	9+9+18	2,62	2,62	5,23	—	—	2,89	10,47	12,30	0,80	3,01	3,81	2,97	5,30	A											
	9+12+12	2,62	3,49	3,49	—	—	2,89	9,60	11,07	0,80	2,76	3,62	2,99	5,30	A											
	9+12+18	2,62	3,49	5,23	—	—	2,89	11,34	11,69	0,80	3,26	3,81	2,94	5,30	A											
	12+12+12	3,49	3,49	3,49	—	—	2,89	10,47	11,07	0,80	3,01	3,73	2,97	5,30	A											
	12+12+18	3,49	3,49	5,23	—	—	2,89	12,20	12,92	0,80	3,51	3,96	2,91	5,30	A											
4 units	9+9+9+9	2,63	2,63	2,63	2,63	—	3,69	10,50	12,92	0,91	3,54	4,19	2,97	5,60	A+											
	9+9+9+12	2,65	2,65	2,65	3,54	—	3,69	11,50	13,53	0,91	3,91	4,19	2,94	5,60	A+											
	9+9+9+18	2,40	2,40	2,40	4,80	—	3,69	12,00	13,53	0,91	4,15	4,38	2,89	5,60	A+											
	9+9+12+12	2,46	2,46	3,29	3,29	—	3,69	11,50	13,53	0,91	3,95	4,19	2,91	5,60	A+											
	9+9+12+18	2,25	2,25	3,00	4,50	—	3,69	12,00	13,53	0,91	4,15	4,38	2,89	5,60	A+											
	9+12+12+12	2,30	3,07	3,07	3,07	—	3,69	11,50	13,53	0,91	3,98	4,19	2,89	5,60	A+											
	9+12+12+18	2,17	2,89	2,89	4,34	—	3,69	12,30	13,53	0,91	4,26	4,38	2,89	5,60	A+											
	12+12+12+12	2,88	2,88	2,88	2,88	—	3,69	11,50	13,53	0,91	3,98	4,19	2,89	5,60	A+											
5 units	12+12+12+18	2,73	2,73	2,73	4,10	—	3,69	12,30	13,53	0,91	4,26	4,38	2,89	5,60	A+											
	9+9+9+9+9	2,46	2,46	2,46	2,46	2,46	4,18	12,30	14,00	1,03	3,81	4,57	3,23	5,80	A+											
	9+9+9+9+12	2,31	2,31	2,31	2,31	3,08	4,18	12,87	14,00	1,03	3,98	4,57	3,23	6,11	A+											
	9+9+9+9+18	2,05	2,05	2,05	2,05	4,10	4,18	12,18	14,00	1,03	3,74	4,57	3,25	5,77	A+											
	9+9+9+12+12	2,17	2,17	2,17	2,89	2,89	4,18	12,68	14,00	1,03	3,93	4,57	3,23	6,06	A+											
	9+9+9+12+18	1,94	1,94	1,94	2,59	3,88	4,18	12,96	14,00	1,03	4,01	4,57	3,23	5,77	A+											
9+9+12+12+12	2,05	2,05	2,73	2,73	2,73	4,18	12,78	14,00	1,03	3,96	4,57	3,23	6,24	A++												
Available combinations																										
Heating		Heating capacity								Power input			COP (W/W)	SCOP Average Season	Energy Class Average	SCOP Warmer Season	Energy Class Warmer Season									
	UI combinations	Each room (kW)					Total (kW)			(kW)																
		A	B	C	D	E	min	nominal	max	min	rating	max														
2 units	9+12	2,91	3,89	—	—	—	2,34	6,80	8,62	0,56	1,79	2,26	3,80	3,00	C	—	—									
	9+18	2,93	5,87	—	—	—	2,34	8,80	11,08	0,56	2,32	2,49	3,80	3,00	C	—	—									
	12+12	3,75	3,75	—	—	—	2,34	7,50	9,23	0,56	1,97	2,36	3,80	3,00	C											

5 units	9+9+9+9+18	2,05	2,05	2,05	2,05	4,10	4,19	12,84	14,96	0,90	3,35	4,15	3,83	3,74	A	5,04	A++
	9+9+9+12+12	2,17	2,17	2,17	2,90	2,90	4,19	12,76	14,96	0,90	3,43	4,15	3,72	3,66	A	4,89	A++
	9+9+9+12+18	1,94	1,94	1,94	2,59	3,89	4,19	12,89	14,96	0,90	3,30	4,15	3,90	3,76	A	5,07	A++
	9+9+12+12+12	2,05	2,05	2,74	2,74	2,74	4,19	12,77	14,96	0,90	3,43	4,15	3,72	3,65	A	4,87	A++